

PERMIT VALID FOR
5 YEARS FROM
DATE OF ISSUE

PERMIT NUMBER 3598

GRANVILLE-VANCE DISTRICT HEALTH DEPARTMENT IMPROVEMENT AND OPERATION PERMITS

COUNTY:	TAX NO.	TYPE OF ESTABLISHMENT			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS. *THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED. *THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USES CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
<u>Vance</u>	SR. NO.	RESIDENCE ☒	NUMBER OF BEDROOMS:	NUMBER OF OCCUPANTS:	
OWNER:		BUSINESS ☐			
		OTHER ☐	<u>3</u>	<u>6</u>	
APPLICANT:		WATER SUPPLY			
APPLICANT'S ADDRESS:		PUBLIC ☐	WELL ☒	OTHER ☐	
PROPERTY ADDRESS/LOCATION:		TYPE OF WASTEWATER SYSTEM			
<u>Wheat Rd</u>		DESCRIPTION	INITIAL INSTALLATION	REPAIR	
SUBDIVISION: <u>Farmington Bldg</u>		DESIGN FLOW:	<u>360 g/day</u>		
LOT NUMBER: <u>27</u>		LTAR:	<u>.35</u>		
REFERENCE SKETCH (SEE PLAT FOR DETAILS)		ABSORPTION AREA:	<u>1,032 ft²</u>		
		TRENCH WIDTH:	<u>3'</u>		
		TRENCH SPACING:	<u>9'</u>		
		TOTAL TRENCH LENGTH:	<u>344' ±</u>		
		NUMBER OF TRENCHES:	<u>4</u>		
		GRAVEL DEPTH:	<u>12"</u>		
		TANK SIZE:	<u>1,000 g</u>		
		CONDITIONS:	<u>24' TD</u>		
FOR: <u>Don Mark Const.</u> ISSUED BY: <u>Mac Shingleton, RS</u> DATE: <u>5-9-03</u>				IMPROVEMENT PERMIT DATE:	
SYSTEM INSTALLED BY: <u>James Bailey</u> ISSUED BY: <u>J. B. Clayton, RS</u> DATE: <u>7-25-03</u>				OPERATION PERMIT DATE:	