

TYPE II A - CONVENTIONAL - ORIGINAL REPAIR

*X MAY HAVE TO BE PUMPED DEPENDING ON HOUSE LOCATION
 PERMIT NUMBER 3804

GRANVILLE-VANCE DISTRICT HEALTH DEPARTMENT IMPROVEMENT AND OPERATION PERMITS

COUNTY: VANCE	TAX NO.	TYPE OF ESTABLISHMENT			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.
	SR. NO.	RESIDENCE <u>X</u> BUSINESS <u>—</u> OTHER <u>—</u>	NUMBER OF BEDROOMS: 4	NUMBER OF OCCUPANTS: ≤ 8	
OWNER: <u>T & W INVESTMENTS</u> <u>Roger Castonguey</u>					
APPLICANT: <u>W.A. CURRIN</u>		WATER SUPPLY			
APPLICANT'S ADDRESS:		PUBLIC <u>—</u>	WELL <u>X</u>	OTHER <u>—</u>	*THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED.
PROPERTY ADDRESS/LOCATION: 429 BENJAMIN HARRISON LN		TYPE OF WASTEWATER SYSTEM			
		DESCRIPTION	INITIAL INSTALLATION	REPAIR	
SUBDIVISION: <u>SOMERSET PLANTATION</u>		DESIGN FLOW:	480 gpd/day		
LOT NUMBER: 47		LTAR:	0.25		
REFERENCE SKETCH (SEE PLAT FOR DETAILS) *SEE ATTACHED LAYOUT *18" TRENCH DEPTH = NO DEEPER!! =		ABSORPTION AREA:	1920 FT²		
		TRENCH WIDTH:	3'		
		TRENCH SPACING:	AT LEAST 9' ON CENTERS		
		TOTAL TRENCH LENGTH:	640'		
		NUMBER OF TRENCHES:	2-3		
		GRAVEL DEPTH:	12"		
		TANK SIZE:	1020 GAL		
		CONDITIONS:	*18" TRENCH DEPTH		*THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USES CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
IMPROVEMENT PERMIT		Updated DATE: 9-8-09 mds 9-22-04			
FOR: <u>T & W INVESTMENTS</u> ISSUED BY: <u>B. L. L.</u>					
OPERATION PERMIT		DATE:		PERMIT VALID FOR 5 YEARS FROM DATE OF ISSUE	
SYSTEM INSTALLED BY:					
ISSUED BY:					