

- 25% REDUCTION SYSTEM - ORIGINAL & REPAIR

*** PURPOSE USE NON COTTON FILTER CLOTH IF CHAMBER SYSTEM IS INSTALLED**

PERMIT NUMBER **4319**

3:00 PM

GRANVILLE-VANCE DISTRICT HEALTH DEPARTMENT IMPROVEMENT AND OPERATION PERMITS

COUNTY: VANCE		TAX NO. 0407A02001		TYPE OF ESTABLISHMENT			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.
OWNER: GLADYS BETHUA		SR. NO.		RESIDENCE ☒	NUMBER OF BEDROOMS: 4300	NUMBER OF OCCUPANTS: 4	
APPLICANT: TOWN & COUNTRY HOMES CHRIS PHILLIPS				WATER SUPPLY 1-11-05			
APPLICANT'S ADDRESS:		PUBLIC ☐		WELL ☒	OTHER ☐		
PROPERTY ADDRESS/LOCATION: 75 SPRING HILL LN. 2nd Lot on LEFT		TYPE OF WASTEWATER SYSTEM					*THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED.
SUBDIVISION: SPRING HILL ESTATES		DESCRIPTION		INITIAL INSTALLATION: 08-1-11-05	REPAIR		
LOT NUMBER: 11 8567		DESIGN FLOW:		360 480 gpd			
REFERENCE SKETCH (SEE PLAT FOR DETAILS) * SEE ATTACHED LAYOUT OVER - 4 STD - W		LTAR:		0.25	1-11-05		
		ABSORPTION AREA:		1440 FT² 1920 FT²			
		TRENCH WIDTH:		3'			
		TRENCH SPACING:		AT LEAST 9' min CENTERS 46'	1-11-05		
		TOTAL TRENCH LENGTH:		360 480	1-11-05		
		NUMBER OF TRENCHES:		4			
		GRAVEL DEPTH:		N/A			
		TANK SIZE:		1000 GAL			
CONDITIONS:		24"-36" TRENCH DEPTH					
IMPROVEMENT PERMIT						DATE:	
FOR: GLADYS BETHUA						1-5-05	
ISSUED BY: Paul L. Yan							
OPERATION PERMIT						DATE:	
SYSTEM INSTALLED BY: HARICA STRICKLAND						4-20	
ISSUED BY: Paul L. Yan						PERMIT VALID FOR 5 YEARS FROM DATE OF ISSUE	