

NOW EXPIRED

PERMIT NUMBER 2572

GRANVILLE - VANCE DISTRICT HEALTH DEPARTMENT
IMPROVEMENT AND OPERATION PERMITS

COUNTY: <i>Vance</i>	TAX NO. <i>Diamond Dr.</i>	TYPE OF ESTABLISHMENT			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.
OWNER: <i>Elizabeth Parker</i>		RESIDENCE ☒ BUSINESS ☐ OTHER ☐	NUMBER OF BEDROOMS: <i>3</i>	NUMBER OF OCCUPANTS: <i>5</i>	
APPLICANT: <i>same</i>		WATER SUPPLY			
APPLICANT'S ADDRESS:		PUBLIC ☐	WELL ☒	OTHER ☐	
PROPERTY ADDRESS/LOCATION: <i>Pool Rock Plantation</i>		TYPE OF WASTEWATER SYSTEM			*THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED.
		DESCRIPTION	INITIAL INSTALLATION	REPAIR	
SUBDIVISION: <i>Pool Rock</i>		DESIGN FLOW:	<i>360</i>		
LOT NUMBER: <i>3</i>		LTAR:	<i>.35</i>		
REFERENCE SKETCH (SEE PLAT FOR DETAILS) <i>System may require pump Layout to be determined when lot cleared. Call Health Dept. before any construction</i>		ABSORPTION AREA:	<i>1028</i>		
		TRENCH WIDTH:	<i>3</i>		
		TRENCH SPACING:	<i>9'</i>		
		TOTAL TRENCH LENGTH:	<i>340'</i>		
		NUMBER OF TRENCHES:	<i>4-6</i>		
		GRAVEL DEPTH:	<i>12"</i>		
		TANK SIZE:	<i>1000</i>		
		CONDITIONS:			
IMPROVEMENT PERMIT				DATE:	*THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USE CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
FOR: ISSUED BY: <i>Walter D. Vaughn RS</i>				<i>6-22-2000</i>	
OPERATION PERMIT				DATE:	
SYSTEM INSTALLED BY:					
ISSUED BY:					