

* Revised to Conv. System
8-3-2009 by MDS

PERMIT NUMBER 3842

GRANVILLE-VANCE DISTRICT HEALTH DEPARTMENT
IMPROVEMENT AND OPERATION PERMITS

COUNTY:	TAX NO.	TYPE OF ESTABLISHMENT			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.
Vance	SR. NO.	RESIDENCE ☒ BUSINESS ☐ OTHER ☐	NUMBER OF BEDROOMS:	NUMBER OF OCCUPANTS:	
OWNER: Al & Joelle Justin D. Ayscue			3	56	*THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED.
APPLICANT:	WATER SUPPLY				
APPLICANT'S ADDRESS: 0593A010616		PUBLIC ☒	WELL ☐	OTHER ☐	*THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USES CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
PROPERTY ADDRESS/LOCATION: Cedar Cove Rd.	Conv. Type #1 TYPE OF WASTEWATER SYSTEM CONCRETE TANK				
	DESCRIPTION	INITIAL INSTALLATION	REPAIR NA		
SUBDIVISION: Cedar Cove LOT NUMBER: 21 Meekins Marina 21 Ing.	DESIGN FLOW:	360 g/day			
	LTAR:	.4			
REFERENCE SKETCH (SEE PLAT FOR DETAILS)	ABSORPTION AREA:	840 840 ft ²			
	TRENCH WIDTH:	3'			
	TRENCH SPACING:	9'			
	TOTAL TRENCH LENGTH:	280 280'			
	NUMBER OF TRENCHES:	4			
	GRAVEL DEPTH:	NA			
	TANK SIZE:	1,000 g			
	CONDITIONS:	30" Maximum Trench Depth			
IMPROVEMENT PERMIT				DATE:	
FOR: Justin D. Ayscue				1-14-05	
OPERATION PERMIT				DATE:	
SYSTEM INSTALLED BY: Pearce Backhoe				8-25-09	
ISSUED BY: Mac Shingleton, R.S.					