

GRANVILLE VANCE

public health

OPERATION PERMIT

Vance County Health Dept
Environmental Health
115 Charles Rollins Road
Henderson, NC 27536

Phone: (252) 492-5263 Fax: (252) 492-2361

For Office Use Only

*CDP File Number 364291 - 1

County ID Number: 045304902

Evaluated For: REPAIR

Property Owner: Charles L. Allen, Jr.

Address: 5036 S. Links Circle

Road #:

City: Suffolk

State/Zip: VA/ 23435

Phone #: (757) 288-9539

Township:

Subdivision:

Phase : NEW

Lot:

Structure: SINGLE FAMILY

of Bedrooms: 2

of People:

Water Supply: EXISTING WELL

Saprolite System?: ☐ Yes ☒ No

Pump Required?: ☐ Yes ☒ No

Design Flow: 240

System Classification/Description: Tap Connection

Installer: KT MOORE SEPTIC SERVICE

Certification #: 12611

Specific System UNKNOWN

Installed:

STB: 789

PT:

Septic Tank Date: 09/28/2021

Pump Tank Date: _____

Comments: TANK REPLACEMENT ONLY.

This system has been installed in compliance with applicable NC General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the improvement Permit and Construction Authorization.

PERMIT CONDITIONS:

1. Performance: System shall perform in accordance with Rule .1961.
- II. Monitoring: As required by Rule .1961.
- III. Maintenance: Ground absorption sewage treatment and disposal systems shall be checked, and the contents of the septic tank removed, periodically from all compartments, to ensure proper operation of the system. The contents shall be pumped whenever the solids level is found to be more than 1/3 of the liquid depth in any compartment.

Other:

Subsurface Operator Required: ☐ Yes ☒ No

If yes, see attached sheet for additional operation conditions, maintenance and reporting.

Operation:

Other: TANK REPLACEMENT ONLY.

Authorized State Agent: Adcock, Jordan

Date of Issue: 11/10/2021

Owner/Applicant:

K.T. Moore Septic Tank Service, Inc. **INVOICE**

712 North Charles Street
Raleigh, NC 27604

919-438-0025 - office
919-438-1838 - mobile
E-Mail: ktm@mooreseptic.com

Mr. Benjamin H.
Henderson
27537
10-14-21

Client Name: Charles Allen Jr.
5036 S. Lake Circle
Suwanee, GA 30066
770-277-9535

Item	Unit	Amount	Notes
Septic Tank Empty			
Septic Tank # 3600			
Septic Tank Replacement			
Septic Tank Pump & Fill in			
Install new Septic Tank Pump			Plastic
with Pump Inlet & Filter			Check
New O-Ring, 1/2" Hose		35.00	
Septic Tank Pump & Fill in			Plastic
Old Basin Light			Plastic
will do job 1/2" Hose			Plastic
License Number: 4010			
Inspector Number: 1201			
Compliance Number: 1201			

SEE UPON RECEIPT
THANK YOU FOR YOUR BUSINESS

