

PERMIT NUMBER 1744

GRANVILLE - VANCE DISTRICT HEALTH DEPARTMENT IMPROVEMENT AND OPERATION PERMITS

COUNTY:	TAX NO.	TYPE OF ESTABLISHMENT			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS *THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED *THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USE CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL
Vance	SR NO 1329	RESIDENCE ☒	NUMBER OF BEDROOMS	NUMBER OF OCCUPANTS	
OWNER: Joseph A Davis		BUSINESS ☐	3	1	
		OTHER ☐			
APPLICANT: Joseph A Davis		WATER SUPPLY			
APPLICANT'S ADDRESS: 2191 Mc ...		PUBLIC ☐	WELL ☒	OTHER ☐	
PROPERTY ADDRESS/LOCATION: Stagecoach Rd		TYPE OF WASTEWATER SYSTEM			
		DESCRIPTION	INITIAL INSTALLATION	REPAIR	
SUBDIVISION:		DESIGN FLOW:	3600 gpm		
LOT NUMBER: A		L.T.A.R.	3		
REFERENCE SKETCH (SEE PLAT FOR DETAILS) back dig trench 4' deep 10' x 20' hole (well) in east of Stagecoach Rd back 5' from house to have properly installed 4' x 10' tank with well. Do not put in call for inspection Must have the permit		ABSORPTION AREA:	1200 sq ft		
		TRENCH WIDTH:	3'		
		TRENCH SPACING:	10' center		
		TOTAL TRENCH LENGTH:	400 ft		
		NUMBER OF TRENCHES:	5 or more		
		GRAVEL DEPTH:	12"		
		TANK SIZE:	1000 gal		
IMPROVEMENT PERMIT		DATE:			
FOR: Joseph A Davis III		2/17/99			
ISSUED BY: J. H. ...					
OPERATION PERMIT		DATE:			
SYSTEM INSTALLED BY: Freddie Williams		12-29-99			
ISSUED BY: ...					