



OPERATION PERMIT

Franklin County Health Department
107 Industrial Drive
Louisburg, NC 27549
Phone:

For Office Use Only

*CDP File Number 451489 - 1
County ID Number: _____
Evaluated For: REPAIR

Property Owner: Sheri Lowery
Owner Address: 604 Holden Rd

City: Youngsville
State/Zip: NC/ 27596
Phone #:
Address: 435 Tant Rd
Zebulon, NC 27597

Road #:
Township:
Subdivision:
Phase : NEW Lot:

Structure: SINGLE FAMILY
of Bedrooms: 3
of People: 4
Water Supply: EXISTING WELL
Saprolite System?: ☐ Yes ☒ No
Pump Required?: ☐ Yes ☒ No
Design Flow: 360
System Classification/Description: TYPE II A. CONV SYSTEM
(SINGLE-FAMILY OR 480 GPD OR LESS)

Installer: New Day Septic
Specific System UNKNOWN
Installed:
STB: 1000 DB-1000
PT:

Certification #:

Septic Tank Date: _____

Pump Tank Date: _____

Comments:

* New Septic tank installed *

This system has been installed in compliance with applicable NC General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.

PERMIT CONDITIONS:

I. Performance: System shall perform in accordance with Rule .1301.

II. Monitoring: As required by Rule .1301.

III. Maintenance: Ground absorption sewage treatment and disposal systems shall be checked, and the contents of the septic tank removed, periodically from all compartments, to ensure proper operation of the system. The contents shall be pumped whenever the solids level is found to be more than 1/3 of the liquid depth in any compartment.

Other:

Subsurface Operator Required: ☐ Yes ☒ No

If yes, see attached sheet for additional operation conditions, maintenance and reporting.

Operation:

Other:

Authorized State Agent: Bendel, Joel

Date of Issue: 04/07/2025

Owner/Applicant: _____