



OPERATION PERMIT

Franklin County Health Department
107 Industrial Drive
Louisburg, NC 27549
Phone:

For Office Use Only

*CDP File Number 321116 - 1
County ID Number: 1846-30-0064
Evaluated For: NEW

Property Owner: NORTH CAROLINA EXTERIORS

Address: 1422 WALL RD

Road #:

City: WAKE FOREST

State/Zip: NC/ 27587

Phone #: (919) 229-5742

Township:

Subdivision:

Phase : NEW

Lot:

Structure: SINGLE FAMILY

of Bedrooms: 3

of People: 4

Water Supply: NEW WELL

Saprolite System?: ☐ Yes ☒ No

Pump Required?: ☐ Yes ☒ No

Design Flow: 360

System Classification/Description: TYPE III B. SYSTEM
WSINGLE EFFLUENT PUMP

Installer: David Truelove

Specific System EZFLOW EZ 1203H-GEO
Installed:

STB: 502

PT:

Comments:

Certification #: 1243

Septic Tank Date: 06/20/2020

Pump Tank Date: 08/12/2020

This system has been installed in compliance with applicable NC General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.

PERMIT CONDITIONS:

I. Performance: System shall perform in accordance with Rule .1961.

II. Monitoring: As required by Rule .1961.

III. Maintenance: Ground absorption sewage treatment and disposal systems shall be checked, and the contents of the septic tank removed, periodically from all compartments, to ensure proper operation of the system. The contents shall be pumped whenever the solids level is found to be more than 1/3 of the liquid depth in any compartment.

Other:

Subsurface Operator Required:

☐ Yes

☒ No

If yes, see attached sheet for additional operation conditions, maintenance and reporting.

Operation:

Other:

Authorized State Agent: Ennis, Crystal

Date of Issue: 11/24/2020

Owner/Applicant:

