

FRANKLIN COUNTY HEALTH DEPARTMENT

PERMIT NUMBER: 8869C	CONST IMPROVE PERMIT	DATE: 11.21.96	23765	SIZE:
APPLICANT: MITCHELL JIMMY L RT 2 BOX 226-1 FUGUAY VARINA NC 27526 TELEPHONE: 552-9294		OWNER: MITCHELL JIMMY L RT 2 BOX 226-1 FUGUAY VARINA NC 27526		
COMMENT:		DESCRIPTION: 5 YEAR ☒ LIFETIME: ☐		
CAMPER LOT				
LOCATION / DIRECTIONS:				
LAKE ROYALE # 235		SIGNATURE OF OWNER OR AUTHORIZED AGENT: <i>Brian Hays</i>		
FEE: 100.00 3708				
THE ABOVE SIGNATURE INDICATES THAT I HAVE READ, UNDERSTAND, AND AGREE WITH ALL PROVISIONS AND INFORMATION AS OUTLINED ON THE BACK SIDE OF THIS FORM				
TOPQ <u>PS</u>	TEXTURE <u>PS</u>	STRUCTURE <u>PS</u>	DEPTH <u>PS</u>	
R. HOR <u>PS</u>	SOIL. WET <u>PS</u>	AVAIL. SP <u>5</u>	OTHER	
MINRL <u>PS</u>	OVERALL <u>PS</u>	LTAR <u>.4</u>		
#BEDRMS <u>2</u>	GPD <u>240</u>	DISPOSAL <u>—</u>	TYPE. SYS <u>Chambered</u>	
SZ. TANK <u>900</u>	SZ. CHAMB <u>—</u>	NITRIFI <u>150' chambered</u>	TYPE. WAT <u>Private</u>	
SITE. LOC <u>—</u>	MAX TRENCH DEP <u>24"</u>	TYP. FAC <u>Camper</u>		
REMARKS: 1) Trailer must set at 30' setback from front prop. line 2) Use chambered system. 3) Keep SYS. 5' off prop lines				
D-B STB 646 CAP 1000 Camper 150' total				
IMPROVEMENT PERMIT DATE: 12/3/96		ENV HEALTH SPEC: <i>[Signature]</i>		
CONSTRUCTION AUTHORIZATION DATE: 12/3/96		ENV HEALTH SPEC: <i>[Signature]</i>		
OPERATION PERMIT DATE: 2/10/97		ENV HEALTH SPEC: <i>[Signature]</i>		