

919-510-0710

**Franklin County Health Department
Environmental Health Section
107 Industrial Drive-Suite C
Louisburg, North Carolina 27549**

PAGE 1 OF 2

DocuSigned by:
S10ABAE933F4AF
DocuSigned by:
Michelle Y. Y. Y.
2B766510674E45B...

Phone: 919-496-8100

Fax: 919-496-8136

Permit Number: 1984 Type: I PIN: 1852-05-8990 Date: 10/13/2005

Applicant: BANNERMAN & CO
PO BOX 669
WAKE FOREST, NC 27588Owner: PATTERSON WOODS LLC
833-A WAKE FOREST BUS PARK
WAKE FOREST, NC 27587

Telephone: (919) 556-4300

Telephone: (919) 556-2519

Subdivision: PATTERSON WOODS

Lot Number: 48

Size: 0.510

Physical Address/ Location /Directions 119 PATTERSON DRIVE

Description: LifeTime _____ 5 Year ☒TYPE FACIL RES # EMPLOY _____ # BEDRMS 3 GPD 360 LTAR .27TYPE WAT Public TYPE SYS Pt to PPBPS TYPE REP Pt to PPBPS BSMT No BST FX N/ASIZE TANK 1000 SIZE CHB 1000 SIZE NITR 3'x238' MTD 28"COMMENTS Install system ~~res~~ ^{drain} Attached layout by Engineer.
House shall not have foundation drains per HD and
Soil Scientist. If any questions call HD 496-8100

Septic Contractors are responsible for notifying the health department for final inspections, between 8:00-9:00 AM on the day of completion, Monday - Friday. Any request for final inspections received afterwards will be scheduled the same day, if possible, or the next workday. Have permit number and owner/applicant's name ready when making the call.

Actions of representatives of state or local agencies engaged in the evaluation and determination of measures required to effect the compliance with the provisions of this permit shall in no way be taken as a guarantee that wastewater disposal systems permitted and approved will function in a satisfactory manner for any given period of time, or that such employees assume any liability for damages, consequential or direct which are caused, or may be caused, by a malfunction of this wastewater treatment and disposal system.

Proper precautions must be taken to assure the proper functioning of the system after it has been covered. Do not run any heavy equipment over the system, as soft earth will allow damage to the tank and lines. Pipe all roof drains away from the septic system site to prevent flooding of the lines from surface water. Terrace the ground to prevent excessive drainage from higher areas adjacent to the system. Do not construct driveways over any part of the septic system unless proper provisions were made when the septic system was constructed. Only grass, not trees or shrubbery, should be cultivated over the lines. All plumbing fixtures should be carefully inspected periodically and any problems repaired immediately. All septic tanks should be pumped off by a permitted pump operator on a regular schedule, not to exceed every five years.

The improvement permit and construction authorization is a site approval, for the future installation of a wastewater treatment and disposal system. Changes in ownership of the site do not affect the validity of this permit. However, any alteration of the site or soil conditions, changes in the location of the proposed facility, changes to the wastewater flow and/or characteristics, or submittal of false information with the application or misrepresentation of the property lines may subject this permit to suspension or revocation.

**FOR THIS TO BE A VALID CONSTRUCTION AUTHORIZATION, A LAYOUT SHEET MUST BE
ATTACHED**

IMPROVEMENT PERMIT

DATE 4/20/06 EHS

CONSTRUCTION AUTHORIZATION

DATE 4/20/06 EHS

Shad Leonard / *Chi*
Shad Leonard / *Chi*

PAGE 2 OF 2

Franklin County Health Department

Name: BANNERMAN & CO

Permit Number

1984

CONTRACTOR

Ferguson's Farm

TANK MANU

mills 1000 SF

MANU DATE

6-5-06

WELL INSTALLED

YES

NO

SYSTEM CODE

PPBS-W-P

SEPTIC SYSTEM LAYOUT

(SKETCH SYSTEM LAYOUT HERE)

See attached paperwork.



SEPTIC SYSTEM AS-BUILT

(IF DIFFERENT FROM INITIAL LAYOUT)

ON REVERSE

OPERATIONS PERMIT

DATE

10-9-06

EHS