

INVOICE

Bill To

Mary Kuga
1165 john mitchell rd
youngsville, NC
(919) 609-7979

J C Madden Company

5601 Tyson Farm Road
Wake Forest, North Carolina 27587
Phone: (919) 730-4591
Email: zonker6738@gmail.com

Payment terms 15 Days
Invoice # 984
Date 05/12/2025
Business / Tax # nc certified septic installer 4 / inspector #4586i

05/13/25

Description

Total

ASSESS SEPTIC SYSTEM \$285.00

ASSESS SEPTIC

find and flag septic tank ,excavate outlet of tank and check outlet tee, baffle wall and solids level in tank

walk area of drainfield and check for past signs of malfunction.....suspect drainfield snakes back and forth in backyard area
original permit could not be found

tank appears to be 1000 or 1200 gallon tank , suitable for a 4 bedroom house in franklin county
tank appears to be in overall good condition, baffle wall is intact and outlet PVC tee is in good condition
solids level in tank indicate it should be pumped at this time, owner agreed and will call septic pumper

actual drain lines and distribution box where not located due to unknown system layout, system has been unused for several years due to house being vacant
no indications of past drainfield malfunction were seen during site visit, at time of inspection

No other signs of malfunction were noted at time of inspection

age of system is unknown, history of system is also unknown

2010 Summerdall Release

Subtotal \$285.00

Total \$285.00