

LiveGreen

ENERGY EFFICIENCY CERTIFICATE

This Certificate shall list the value covering the largest area

Builder, Permit Holder or Registered Design Professional

Print Name: _____

Signature: _____

Property Address: 10 Princeton Manor Drive

Permit Date: 3-13-13

Insulation Rating - List the value covering the largest area to all that apply

Ceiling/Roof:

Wall:

Floor:

Closed Crawl Space Wall:

Closed Crawl Space Floor:

Slab:

Basement:

Fenestration:

U-Factor

Solar Heat Gain Coefficient (SGHC)

Building Air Leakage

Visually Inspected according to 402.4.2.1 OR

Building Air Leakage Test

Results:

(Sec 402.4.2.2)

ACH50 [Target 5.0] or

CFM50/SFSA [Target .30]

Name of Tester/Company: LiveGreen

Date: 3/13/13

HERS Rater #: 3491453

Phone: 919-463-0601

Ducts

Insulation: Must be min of R6

Total Duct Leakage Test Result (Sec 403.2.2)

(CFM25 Total/100SF) [Target 6] 60 CFM x 100 / 3420 SF = 1.8 CFM25

Name of Tester/Company: LiveGreen

Date: 3/13/13

HERS Rater #: 3491453

Phone: 919-463-0601

Certificate to be displayed permanently