

Franklin County Health Department
Division of Environmental Health
107 Industrial Drive-Suite C
Louisburg, North Carolina 27549

PAGE 1 OF 2

Phone: 919-496-8100

SEPTIC PERMIT

Fax: 919-496-8136

Permit Number: 9260 Type: I PIN: 1842-38-3020 Date: 3/10/2017

Applicant: DESIGN HOME RENOVATIONS Owner: CHARLES & BARBARA MITCHELL
50 LANCE LN 120 MILLIFORD LN
YOUNGSVILLE, NC 27596 DURHAM, NC 27713

Telephone: (919) 291-1982 Telephone:

Subdivision: LYNN OAKS Lot Number: Size: 1.020

Physical Address/ Location /Directions HOLDEN RD

Description: LifeTime _____ 5 Year ☒

TYPE FACIL Res # EMPLOY _____ # BEDRMS 3 GPD 360 LTAR 13

TYPE WAT Country TYPE SYS A TYPE REP PtA BSMT No BST FX N/A

SIZE TANK 1000 SIZE CHB N/A SIZE NITR 3x300' MTD 24"

COMMENTS: Maintain all setbacks. Install system as designed by S+EC.

Septic Contractors are responsible for notifying the health department for final inspections, between 8:00-9:00 AM on the day of completion, Monday - Friday. Any request for final inspections received afterwards will be scheduled the same day, if possible, or the next workday. Have permit number and owner/applicant's name ready when making the call.

Actions of representatives of state or local agencies engaged in the evaluation and determination of measures required to effect the compliance with the provisions of this permit shall in no way be taken as a guarantee that wastewater disposal systems permitted and approved will function in a satisfactory manner for any given period of time, or that such employees assume any liability for damages, consequential or direct which are caused, or may be caused, by a malfunction of this wastewater treatment and disposal system.

Proper precautions must be taken to assure the proper functioning of the system after it has been covered. Do not run any heavy equipment over the system, as soft earth will allow damage to the tank and lines. Pipe all roof drains away from the septic system site to prevent flooding of the lines from surface water. Terrace the ground to prevent excessive drainage from higher areas adjacent to the system. Do not construct driveways over any part of the septic system unless proper provisions were made when the septic system was constructed. Only grass, not trees or shrubbery, should be cultivated over the lines. All plumbing fixtures should be carefully inspected periodically and any problems repaired immediately. All septic tanks should be pumped off by a permitted pump operator on a regular schedule, not to exceed every five years.

The improvement permit and construction authorization is a site approval, for the future installation of a wastewater treatment and disposal system. Changes in ownership of the site do not affect the validity of this permit. However, any alteration of the site or soil conditions, changes in the location of the proposed facility, changes to the wastewater flow and/or characteristics, or submittal of false information with the application or misrepresentation of the property lines may subject this permit to suspension or revocation.

FOR THIS TO BE A VALID CONSTRUCTION AUTHORIZATION, A LAYOUT SHEET MUST BE ATTACHED

IMPROVEMENT PERMIT

DATE 3-23-17 EHS Shel Fenner

CONSTRUCTION AUTHORIZATION

DATE 3-23-17 EHS Shel Fenner

Visit www.franklincountyenvironmentalhealth.com for permit information and tracking.

HOLDEN ROAD 60' PUBLIC R/W

N 80°54'52" E

99.77' N 84°22'09" E

99.76'

32&33

TOTAL AREA = 1.062 AC.
LESS R/W - 0.133 AC.
NET AREA = 0.928 AC.

S 03°12'54" E

RIP-RAP AREAS

GRAVEL DRIVEWAY

N 10°17'07" W

COVERED PORCH

D-BOX
DWELLING
A/C UNIT

CREEK

50FT OFF CREEK

60FT EZ-FLOW

60FT EZ-FLOW

60FT EZ-FLOW

60FT EZ-FLOW

60FT EZ-FLOW

SEPTIC TANK LIDS


SEPTIC REPAIR
AREA ~3,700 SQ FT

264.90'

N 87°30'00" W

FENCE

GRAPHIC SCALE
1" = 40'



NOTES:

1) SITE DATA TO INCLUDE PROPERTY BOUNDARIES, STRUCTURE LOCATION, UTILITIES, ROADS, AND OTHER SITE FEATURES WERE PROVIDED BY CAWTHORNE, MOSS, AND PANICERA SURVEYING AND ARE SHOWN TO DISPLAY GENERAL SITE CONDITIONS. THIS IS NOT A SURVEY.

2) ALL SEPTIC SYSTEM COMPONENTS TO INCLUDE TANK AND SYSTEM LINES HAVE BEEN GPS LOCATED. ALL LOCATIONS, ELEVATIONS, AND DIMENSIONS ARE APPROXIMATE AND AS SUCH NO SPECIFIC ACCURACY EITHER VERTICAL OR HORIZONTAL IS IMPLIED.

3) THIS MAP AND CORRESPONDING SITE EVALUATION IS NOT CONFORMANT TO THE ENGINEERED OPTION PERMIT (EOP) PROCESS. ADDITIONAL SITE TESTING AND EVALUATIONS WILL BE REQUIRED TO UTILIZE THE EOP PROCESS.

4) PROPERTY AND EASEMENT BOUNDARIES SHOWN ON THIS SITE SKETCH ARE APPROXIMATE AND ARE NOT INTENDED FOR LOCATING PROPERTY OR IDENTIFYING PROPERTY OR EASEMENT CORNERS. THIS IS NOT A SURVEY.

5) INITIAL 3-BEDROOM GRAVITY, EZ-FLOW SEPTIC DRAINFIELD AND BRANTLEY & SONS 1,000 GALLON ST 502 SEPTIC TANK WERE INSTALLED ON OCTOBER 10, 2018 AND INSPECTED BY FRANKLIN COUNTY HEALTH DEPT ON THE SAME DAY.

3-BEDROOM GRAVITY SYSTEM
5 - 60FT LINES 0.3 LTAR EZ FLOW
3-BEDROOM PRESSURE MANIFOLD REPAIR
0.3 LTAR EZ FLOW

Property:

1027 HOLDEN ROAD

Location:

FRANKLIN CO., NC

PROPERTY OWNER:

CORY CONNELL

Sheet Title:

AS-BUILT SEPTIC LAYOUT MAP

Scale:
1" = 40'



NORTH

7-14-21
Joel
Bendel

*As-Built
Drawing

Franklin County Health Department

Name: DESIGN HOME REN

Permit Number

9260

CONTRACTOR Tru Works TANK MANU DB-1000
STB-502 MANU DATE 7-21-18
WELL INSTALLED YES _____ NO ☒ SYSTEM CODE EZ1203-N-G

SEPTIC SYSTEM LAYOUT
(SKETCH SYSTEM LAYOUT HERE)

See Attached layout by STEC,

* AS-Built *
5-60' lines

SEPTIC SYSTEM AS-BUILT

(IF DIFFERENT FROM INITIAL LAYOUT)

ON REVERSE

OPERATIONS PERMIT

DATE

10-10-18

EHS

Joel Berdel