



IMPROVEMENT PERMIT

Franklin County Health Department
107 Industrial Drive
Louisburg, NC 27549
Phone: _____

For Office Use Only

*CDP File Number: 370818 - 1
County ID Number: 2830-97-0426
Evaluated For: NEW

PERMIT VALID UNTIL: 03/21/2027

***NOTE TO INSPECTIONS DIVISION:** Building Permits cannot be issued with this Improvement Permit.

Applicant: SANTIAGO AGUILAR
Address: 131 N JUDD PARKWAY SUITE 1733
City: FUQUAY-VARINA
State/Zip: NC 27526
Phone #: _____

Property Owner: JOSEPHINE BULLOCK DAVIS
Address: 5624 N MARWOOD BLVD
City: UPPER MARLBORO
State/Zip: MD. 20772
Phone #: _____

Property Location & Site Information

Address/Road #: 1176 SAGAMORE DR
Subdivision: LAKE ROYALE Phase: NEW Lot: 2241
Structure: LOUISBURG, NC 27549
Directions
of Bedrooms: 3 1176 SAGAMORE DR
of People: 5
*Water Supply: N/A

System Specifications

Initial System

*Site Classification:

Design Flow: 360

Soil Application Rate: 0.3000

*System Classification/Description:

TYPE II A. CONV SYSTEM (SINGLE-FAMILY OR 480 GPD OR
LESS)

*Proposed System:
25% REDUCTION

Minimum Trench Depth: _____ Inches

Maximum Trench Depth: 30 Inches

Septic Tank: 1000 Gallons

Pump Required ☐ Yes ☒ No ☐ May Be Required

Pump Tank: _____ Gallons

Repair System Required: ☐ Yes ☐ No ☐ No, but has Available Space * 15A NCAC 18A. 1945 * Repair Area Exempt

No grading or construction activity is allowed in areas designated for system and repair without approval of Health Department

*Site Modifications

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements.

*Permit Conditions

The Department and Local Health Department may impose conditions on the issuance and may revoke the permits for failure of the system to satisfy the conditions, the rules, or this article. This permit is subject to revocation if the site plan, plat, or intended use changes (NCGS 130A-335(f)). The person owning or controlling the system location, installing, operation, maintenance, monitoring, reporting, and repair (1938(b)).

Authorized State Agent: Bendel, Joel Date of Issue: 03/21/2022

Total Time: (HH:MM)

☐ Hand Drawing

☐ Import Drawing

****Site Plan/Drawing attached.****

_____ : _____



Construction Authorization

Franklin County Health Department
107 Industrial Drive
Louisburg, NC 27549
Phone: _____

For Office Use Only

*CDP File Number: 370818 - 1
County ID Number: 2830-97-0426
Evaluated For: NEW

PERMIT VALID UNTIL: 03/21/2027

☐ Open Pump System Sheet

Applicant: SANTIAGO AGUILAR
Address: 131 N JUDD PARKWAY SUITE 1733
City: FUQUAY-VARINA
State/Zip: NC 27526
Phone #: _____

Property Owner: JOSEPHINE BULLOCK DAVIS
Address: 5624 N MARWOOD BLVD
City: UPPER MARLBORO
State/Zip: MD. 20772
Phone #: _____

Property Location & Site Information

Address/Road #: 1176 SAGAMORE DR Subdivision: LAKE ROYALE Phase: NEW Lot: 2241
LOUISBURG, NC 27549
Directions:
Structure: SINGLE FAMILY 1176 SAGAMORE DR
of Bedrooms: 3
of People: 5
*Water Supply: _____

System Specifications

*Site Classification: _____ Minimum Trench Depth: _____ Inches
Design Flow: 360 Maximum Trench Depth: 30 Inches
Soil Application Rate: 0.3000 Minimum Soil Cover: _____ Inches
*System Classification/Description: TYPE II A. CONV SYSTEM (SINGLE-FAMILY OR 480 GPD OR LESS) Maximum Soil Cover: _____ Inches
*Proposed System: 25% REDUCTION *Distribution Type: GRAVITY - PARALLEL (eq. d-box)
Nitrification Field: _____ Sq. ft. Septic Tank: 1,000 Gallons
No. Drain Lines: 5 Pump Required: ☐ Yes ☒ No ☐ May Be Required
Total Trench Length: 300 ft. ☐ Inches O.C. Pump Tank: _____ Gallons
☒ Feet O.C. Grease Trap: _____ Gallons
Trench Spacing: _____ - 9 ☐ Inches
Trench Width: _____ - 3 ☒ Feet
Aggregate Depth: _____ inches Septic Tank Installer
Grade Level Required: ☐ I ☐ II ☐ III ☐ IV

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements.

*Permit Conditions:

The Authorization for Wastewater System Construction shall be valid for a period equal to the period of validity of the Improvement Permit and may be issued at the same time the Improvement Permit issued (NCGS 130A-336(b)). If the installation has not been completed during the period of validity of the Construction Permit, the information submitted in the application for a permit or Construction Authorization shall become invalid, and may be suspended or revoked (.1937(g)). The person owning or controlling the system shall be responsible for assuring compliance with the laws, rules, and permit conditions regarding system location, installation, operation, maintenance, monitoring, reporting

Authorized State Agent: Bendel, Joel Date of Issue: 03/21/2022

☐ Hand Drawing ☐ Import Drawing

****Site Plan/Drawing attached.****

Total Time : (HH:MM) _____



Franklin County
215 E. Nash St. Louisburg, NC 27549
Phone (919) 496-2281
www.franklincountync.us

Issued to: Santiago Aguilar

Location: 1176 SAGAMORE DR LOUISBURG , NC 27549

370818 NEW SEPTIC APPLICATION 2830-97-0426

Application Type: NEW SEPTIC

Application Number: E-22-168

Date: February 23, 2022

Building Type:

Acreage: 0.34

Project Type: Single Family Dwelling

Zoning: R-30

of Bedrooms: 3

of People: 5

Parcel ID #: 019680

Subdivision: ROYALE LOT

2241

Applicant Information

Applicant Name: Santiago Aguilar

Address: 131 N Judd Pkwy NE Suite 1733 Fuquay Varina , NC 27526

Phone: 919-335-3699

Email: rhapsody.property.group@gmail.com

Property Owner Information

Owner Name: DAVIS JOSEPHINE BULLOCK

Address: 5624 N MARWOOD BLVD UPPER MARLBORO , MD 20772

Phone:

Email:

General Contractor Information

Contractor Name:

Address: ,

Phone:

Email:

Zoning

Zoning Permit #: Z-22-260

County Water: TESI

Front Setback: 15

Right Setback: 5

Left Setback: 5

Rear Setback: 5

Call Environmental Health (919-496-8100) between 8:00 - 9:00 a.m. Monday - Friday in order to schedule an appointment with and environmental Health Specialist for your lot evaluation. This application for an improvement permit/construction authorization and well permit does not constitute approval for zoning, septic, and building permits. It will be necessary to meet all guidelines for zoning, septic, and building permits prior to construction. The application is valid for either 12 months or without expiration, depending upon documentation submitted.

Please contact the Environmental Health Department at 919-496-8100 to determine the status of your application prior to visiting the Planning & Inspections Department to obtain a building permit.

I hereby certify that I am the owner, or authorized by the owner to act as his/her legal representation. Furthermore, as legal representative (if applicable) I have advised the owner of my intention to apply for this wastewater treatment and disposal system and drinking water and well system permit.

I also certify that all of the statements made in this application and any attached documents are true, complete, and correct, to the best of my knowledge and belief, and are made in good faith. If information in this application for these improvements is falsified, changed or site is altered, then improvement permits and authorization to construct these improvements shall become invalid. Authorized county representatives are granted right of entry to make these evaluations or inspections, and to be release information upon public request.


February 23, 2022

3/2/22, 4:07 PM

Santiago E Aguilar (Manager, Rhapsody Property Group
LLC)


Signature of Owner or Owner's Legal Representative

Expires: February 23, 2023



February 16, 2022

1176 SAGAMORE DR
LOUISBURG, NC 27549



Sources: Esri, HERE, Garmin, USGS, Intermap, INCREMENT P, Japan, METI, Esri China (Hong Kong), Esri Korea, Esri (Thailand) OpenStreetMap contributors, and the GIS User Community



File # 370818 PIN# _____

Property Address: 1176 Sagamore Dr

Applicant or Owner Name: Santiago Aguilar

Environmental Health Septic/Well Permit Diagram

Building permits cannot be issued nor should construction begin without Construction Authorization issuance.

☒ Septic Improvement Permit ☒ Septic Construction Authorization (CA) ☐ CA Reissue** ☐ As Built
☐ Well Construction Authorization ☐ Additional Diagram/Specifications Attached

Diagram Date**: 3-21-22 EHS: Joel Bendel

**Any previously dated CA diagram is revoked and/or invalid. Confirm this is the valid diagram for the site before beginning any construction.

Installation/grouting inspections may be scheduled the day before, or, the day of installation until 9am by contacting the Environmental Health office at 919 496 8100. A revisit fee may apply if installation is not ready for inspection at the time requested. Septic Operations Permits will be issued after installation is approved, all permits conditions are met, and any outstanding fees are paid. Well Certificate of Completion will be issued after well head approval, all permit conditions are met, and any outstanding fees are paid.

Septic Tank 1000 Pump Tank N/A Drainfield 3'x300' Type System ACC Max Trench Depth 30"

Septic Contractor _____ Septic/Pump tank dates _____ Pump fee? NO YES pd _____

Well Contractor _____ Well Grout date: _____

Bedrooms: _____

★ Drawing not to scale

