

Franklin County Health Department
Environmental Health Section
107 Industrial Drive-Suite C
Louisburg, North Carolina 27549

PAGE 1 OF 2

Phone: 919-496-8100

Fax: 919-496-8136

Permit Number: 219 Type: I PIN: 1870-70-6058 Date: 2/16/04
Applicant: SUMNER CONSTRUCTION INC Owner: DENMARK CONSTRUCTION INC
PO BOX 1011 416 US HWY 1 STE B
YOUNGSVILLE, NC 27596 YOUNGSVILLE, NC 27596
Telephone: (919) 422-5713 Telephone:
Subdivision: BARHAM PLACE Lot Number: 43 Size: .920

Physical Address/ Location /Directions TWO PINES TRAIL

Description: LifeTime 5 Year ☒

TYPE FACIL Residence # EMPLOY # BEDRMS 4 GPD 480 LTAR 0.35
TYPE WAT PRIVATE TYPE SYS Innov TYPE REP Innov BSMT N/A BST FX N/A
SIZE TANK 1000 SIZE CHB 1000 SIZE NTR 3'x4' MTD 24"

COMMENTS * Install Approved Pressure Manifold to
Innovative System along Contour in Dry
Conditions!
* Do Not Park or Drive over SYSTEM AREA

Septic Contractors are responsible for notifying the health department for final inspections, between 8:00-9:00 AM on the day of completion, Monday - Friday. Any request for final inspections received afterwards will be scheduled the same day, if possible, or the next workday. Have permit number and owner/applicant's name ready when making the call.

Actions of representatives of state or local agencies engaged in the evaluation and determination of measures required to effect the compliance with the provisions of this permit shall in no way be taken as a guarantee that wastewater disposal systems permitted and approved will function in a satisfactory manner for any given period of time, or that such employees assume any liability for damages, consequential or direct which are caused, or may be caused, by a malfunction of this wastewater treatment and disposal system.

Proper precautions must be taken to assure the proper functioning of the system after it has been covered. Do not run any heavy equipment over the system, as soft earth will allow damage to the tank and lines. Pipe all roof drains away from the septic system site to prevent flooding of the lines from surface water. Terrace the ground to prevent excessive drainage from higher areas adjacent to the system. Do not construct driveways over any part of the septic system unless proper provisions were made when the septic system was constructed. Only grass, not trees or shrubbery, should be cultivated over the lines. All plumbing fixtures should be carefully inspected periodically and any problems repaired immediately. All septic tanks should be pumped off by a permitted pump operator on a regular schedule, not to exceed every five years.

The improvement permit and construction authorization is a site approval, for the future installation of a wastewater treatment and disposal system. Changes in ownership of the site do not affect the validity of this permit. However, any alteration of the site or soil conditions, changes in the location of the proposed facility, changes to the wastewater flow and/or characteristics, or submittal of false information with the application or misrepresentation of the property lines may subject this permit to suspension or revocation.

FOR THIS TO BE A VALID CONSTRUCTION AUTHORIZATION, A LAYOUT SHEET MUST BE ATTACHED

IMPROVEMENT PERMIT

DATE

2/16/04 EHS

CONSTRUCTION AUTHORIZATION

DATE

2/16/04 EHS

Andy Smith, RS
Andy Smith, RS

Franklin County Health Department


Name: SUMNER CONSTRU

Permit Number

219

CONTRACTOR Triangle Pump & Tank TANK MANU Ellis 1000 MANU DATE _____WELL INSTALLED AT TIME OF INSPECTION YES ☒ NO ☐

SEPTIC SYSTEM LAYOUT (SKETCH SYSTEM LAYOUT HERE)



SEPTIC SYSTEM AS-BUILT (IF DIFFERENT FROM INITIAL LAYOUT) ON REVERSE

OPERATIONS PERMIT

DATE 7/22/04 EHS

Andy Smith RS

		PROFILES					
		1	2	3	4	5	6
LANDSCAPE POSITION	1940	R	S				
SLOPE (%)	1940	2-4	2-6				
HORIZON I DEPTH	1943	0-6	0-12				
TEXTURE	1941(a) (1)	SL	SL				
CONSISTENCE	1941	ER	ER				
STRUCTURE	1941(a)(2)	GR	GR				
CLAY MINEROLOGY	1941(a)(3)	NEXP	NEXP				
HORIZON II DEPTH	1943	6-16	12-20				
TEXTURE	1941(a) (1)	CL	CL				
CONSISTENCE	1941	Fi	Fi				
STRUCTURE	1941(a)(2)	SBK	SBK				
CLAY MINEROLOGY	1941(a)(3)	SEXP	SEXP				
HORIZON III DEPTH	1943	16-36	20-36				
TEXTURE	1941(a) (1)	C	C				
CONSISTENCE	1941	Fi	Fi				
STRUCTURE	1941(a)(2)	SBK	SBK				
CLAY MINEROLOGY	1941(a)(3)	SEXP	SEXP				
HORIZON IV DEPTH	1943						
TEXTURE	1941(a) (1)						
CONSISTENCE	1941						
STRUCTURE	1941(a)(2)						
CLAY MINEROLOGY	1941(a)(3)						
SOIL WETNESS	1941	736"	736"				
RESTRICTIVE HORIZON	1944	736"	736"				
SAPROLITE	1943/1956	36"	736"				
CLASSIFICATION	1948	PS	PS				
LTAR (gpd/ft2)	1955	0.25	0.25				
OTHER FACTORS (1946)							
AVAILABLE SPACE (1945)	PS						
CLASSIFICATION (1948)	PS						
EVALUATED BY:	ANDY S.						
SYSTEM TYPE	Pump to Thrgh						
OTHERS PRESENT							

ENVIRONMENT HEALTH APPLICATION (496-8100)

Permit #: **11247**Permit Type: **SEPTIC PERMIT**Date Issued: **02/13/2004**Project Address: **TWO PINES TRAIL,**

180950

Location: **TWO PINES TRAIL**Size #: **0.920**Subdivision: **BARHAM PLACE**Lot #: **43**Applicant: **SUMNER CONSTRUCTION, INC**Phone: **919.422.5713****PO BOX 1011****YOUNGSVILLE NC 27596**Owner: **DEN MARK CONSTRUCTION INC**

Phone:

P O BOX 610**YOUNGSVILLE, NC 27596**Tax record: **35247**Pin #: **1870-70-6058**Parcel #: **E09A00 043**Zoned: **R 40**Setbacks Front: **50**Rear: **50**Side: **20**Proposed Use: **SFD**# of bedrooms: **3**# of people: **3**Township: **HARRIS**Public Water/Sewer: **PRIVATE**

ST Road #:

Desc:

Fees Due: **\$225.00**Date Paid: **02/13/2004***** Please complete all sections below***

☐ Yes ☒ No Does this site contain any previously identified jurisdictional wetlands?
☐ Yes ☒ No Is any wastewater, other than domestic, going to be generated?
☐ Yes ☒ No Is the site subject to approval by any other public agency?

*If the answer to any of the above is "yes", applicant must submit supporting documentation.

Please indicate desired system type(s). Systems can be ranked in order of preference.

☐ Conventional ☐ Alternative ☐ Innovative ☐ Modified Conventional
☐ Other ☒ No Preference

Call Environmental Health (919.496.8100) between 8:00 - 9:00 am Monday - Friday in order to schedule an appointment with an environmental health specialist for your lot evaluation. This application for an improvement permit/construction authorization does not constitute approval for zoning, septic or building permits. It will be necessary to meet all guidelines for zoning, septic and building permits prior to construction. The permit is valid for either 60 months or without expiration, depending upon documentation submitted. (complete site plan= 60 months---complete surveyed plat=without expiration.)

I hereby certify that I am the owner, or authorized by the owner to act as his/her legal representation. Furthermore, as legal representative (if applicable) I have advised the owner of my intention to apply for this wastewater treatment and disposal system.

I also certify that all of the statements made in this application and any attached documents are true, complete, and correct, to the best of my knowledge and belief, and are made in good faith. If information in application for improvement permit is falsified, changed or site is altered, then improvement permit and authorization to construct shall become invalid. Authorized county representatives are granted right of entry to make evaluations or inspections, and to release information upon public request.

Denise B. Brown
Signature of Owner or Owner's Legal Representative

2/13/04
Date

Zoning Permit #: 7423

Franklin County DRC Application

RESIDENTIAL



ADDRESS: TWO PINES TRAIL

PARCEL NO.: 1870-70-6058

ZONING: R 40

SUBDIVISION: BARHAM PLACE

LOT: 43

ISSUED TO: SUMNER CONSTRUCTION

P O BOX 1011

YOUNGSVILLE, NC 27596

PHONE NUMBER: 919-562-5240

SETBACK: FRONT: 50 RIGHT: 20 LEFT: 20 REAR: 50

COUNTY WATER: NO FLOODPLAIN: NO

PERMIT TYPE: ZONING PERMIT

TYPE OF CONSTRUCTION: SFD

PERMIT DATE: 02/13/2004 WATERSHED NO

TOWNSHIP HAR EXPIRE DATE: 08/13/2004

It is hereby certified that the above use as shown on the plats and plans submitted with this application conforms with all applicable provisions of the Franklin County Zoning Ordinance. The issuance of this application does not allow the violation of Franklin County Zoning Ordinance or other governing regulations. The applicant is responsible for obtaining a building permit (if required) prior to commencing work on the proposed improvement. A final zoning inspection must be scheduled by the applicant.

NOTES:

I hereby certify that all information I have provided to the Planning Department is true and accurate.

APPLICANTS SIGNATURE:

Dennis Brown

UTILITY COMPANY : PROGRESS ENGERY WAKE ELECTRIC OTHER
NUMBER OF STORIES: 1 1 1/2 2 2 1/2
SQUARE FOOTAGE: HEATED UNHEATED TOTAL
BASEMENT: N/A YES NO MANUFACTURED
FIREPLACE: N/A MASONRY MANUFACTURED
PLAN SETS: MODULAR STICKBUILT
ELECTRICIAN: MECHANICAL:
PLUMBING:
MULTI USE PLAN #
COST OF CONSTRUCTION:

NO MORE THAN 2 STRUCTURAL DEVIATIONS OR PLANS MUST BE REDRAWN

DEPARTMENTAL USE ONLY				
	INITIALS (IN)	DATE	INITIALS (OUT)	DATE
ZONING	<i>[Signature]</i>	2/13/04		
INITIAL PERMITTING				
ADDRESSING				
PLAN REVIEW				
FIRE REVIEW				
SEPTIC/SEWER				
FINAL PERMITTING				

R/W - RIGHT OF WAY
 CATV - CABLE TV
 EB - ELECTRIC BOX
 TEL - TELEPHONE
 PP - POWER POLE
 OHL - OVERHEAD
 LP - LIGHT POLE
 () - ADDRESS

Lot 49 Barham Place
 Summer

