

FRANKLIN COUNTY HEALTH DEPARTMENT

PERMIT NUMBER: 16583C CONST IMPROVE PERMIT	DATE: 20020620	1870-70-9125	SIZE: 1.400A
APPLICANT: SUMNER CONST 1265 FLAT ROCK CHURCH RD LOUISBURG NC 27549		OWNER: DENMARK 919-459-6911	
TELEPHONE: 562-5240			
COMMENT: SFD	DESCRIPTION: 5 YEAR ☒		LIFETIME: ☐
LOCATION / DIRECTIONS: BARHAM PLACE #41 - TWO PINES TRAIL			
FEE: 175.00		SIGNATURE OR OWNER OR AUTHORIZED AGENT:	

THE ABOVE SIGNATURE INDICATES THAT I HAVE READ, UNDERSTAND, AND AGREE WITH ALL PROVISIONS AND INFORMATION AS OUTLINED ON THE BACK SIDE OF THIS FORM

TOPO <u>PS</u>	TEXTURE <u>PS</u>	STRUCTURE <u>PS</u>	DEPTH <u>PS</u>
R. HOR <u>PS</u>	SOIL. WET <u>PS</u>	AVAIL. SP <u>PS</u>	OTHER <u>PS</u>
MINRL <u>PS</u>	OVERALL <u>PS</u>	LTAR <u>PS</u>	
#BEDRMS <u>04</u>	GPD <u>\$800</u>	DISPOSAL <u>3' 400'</u>	TYPE. SYS <u>Tanox</u>
SZ. TANK <u>1000gal</u>	SZ. CHAMB <u>1000</u>	NITRIFI <u>3' 400'</u>	TYPE. WAT <u>Public</u>
SITE. LOC <u>PS</u>	MAX TRENCH DEP <u>28"</u>	TYP. FAC <u>SFD</u>	
REMARKS: <u>*DRAWING NOT TO SCALE</u>			

*SYSTEM AREA CAN VARY ONCE EXACT HOME LOC. IS DETERMINED

CONTRACTOR: Triangle Pump & Tank

TANK MANUF: Ellis 1000


MANUF DATE: 5/28/03

* Pump To Pressure Manifold

* ~~Pump at pressure~~

* Install System along Contour & IN DRY Conditions!

* Do Not PARK or Drive Over System AREA!



IMPROVEMENT PERMIT DATE: <u>6/21/02</u>	TWO PINES TR	ENV HEALTH SPEC: <u>Andy Smith, PS</u>
CONSTRUCTION AUTHORIZATION DATE: <u>6/21/02</u>		ENV HEALTH SPEC: <u>Andy Smith, PS</u>