



OPERATION PERMIT

Franklin County Health Department
107 Industrial Drive
Louisburg, NC 27549
Phone:

For Office Use Only

*CDP File Number 361574 - 1
County ID Number: 1880-39-0890
Evaluated For: NEW

Property Owner: COURTNEY WILSON

Address: 3309 COMSTOCK RD

Road #:

City: RALEIGH

State/Zip: NC/ 27604

Phone #:

Township:

Subdivision: REBECCA ACRES

Phase : NEW

Lot: 23

Structure: SINGLE FAMILY

of Bedrooms: 3

of People: 4

Water Supply: N/A

Saprolite System?: ☐ Yes ☒ No

Pump Required?: ☒ Yes ☐ No

Design Flow: 360

System Classification/Description: TYPE III B. SYSTEM
W/SINGLE EFFLUENT PUMP

Installer: DBS

Specific System UNKNOWN

Installed:

STB: 1000

PT: 1000

Comments:

Certification #:

Septic Tank Date: 11/28/2021

Pump Tank Date: 11/18/2021

This system has been installed in compliance with applicable NC General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.

PERMIT CONDITIONS:

I. Performance: System shall perform in accordance with Rule .1961.

II. Monitoring: As required by Rule .1961.

III. Maintenance: Ground absorption sewage treatment and disposal systems shall be checked, and the contents of the septic tank removed, periodically from all compartments, to ensure proper operation of the system. The contents shall be pumped whenever the solids level is found to be more than 1/3 of the liquid depth in any compartment.

Other:

Subsurface Operator Required: ☐ Yes ☒ No

If yes, see attached sheet for additional operation conditions, maintenance and reporting.

Operation:

Other:

Authorized State Agent: Bendel, Joel

Date of Issue: 03/14/2022

Owner/Applicant: _____

