



OPERATION PERMIT

Franklin County Health Department
107 Industrial Drive
Louisburg, NC 27549
Phone:

For Office Use Only

*CDP File Number 298597 - 2

County ID Number: 2830434136

Evaluated For: NEW

Applicant: David Bundy

Property Owner: MITCHELL HOMES INC
Owner Address: 1650 HOLLY HILLS RD

City: POWHATAN
State/Zip: VA/ 23139
Phone #:

Address: 139 CLEAR WATER RD
LOUISBURG, NC 27549

Road #:
Township:
Subdivision: LAKE ROYALE
Phase : ACTIVE Lot: 3296

Structure: SINGLE FAMILY
of Bedrooms: 3
of People: 2 (max 6)

Water Supply: PUBLIC

Saprolite System?: ☐ Yes ☒ No

Pump Required?: ☒ Yes ☐ No

Design Flow: 300

System Classification/Description: TYPE III B. SYSTEM
W/SINGLE EFFLUENT PUMP

Installer: DB & SONS

Certification #: 1036

Specific System POLYSTYRENE AGGREGATE
Installed:

STB: 502

PT: 237

Comments: 300' EZ FLOW INSTALLED

Septic Tank Date: _____

Pump Tank Date: _____

This system has been installed in compliance with applicable NC General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.

PERMIT CONDITIONS:

I. Performance: System shall perform in accordance with Rule .1301.

II. Monitoring: As required by Rule .1301.

III. Maintenance: Ground absorption sewage treatment and disposal systems shall be checked, and the contents of the septic tank removed, periodically from all compartments, to ensure proper operation of the system. The contents shall be pumped whenever the solids level is found to be more than 1/3 of the liquid depth in any compartment.

Other:

Subsurface Operator Required: ☐ Yes ☒ No

If yes, see attached sheet for additional operation conditions, maintenance and reporting.

Operation:

Other: 300' EZ FLOW INSTALLED

Authorized State Agent: Ennis, Crystal

Date of Issue: 08/27/2025

Owner/Applicant: _____

File # 298597

PIN# _____

Property Address: 139 Clearwater Rd

Applicant or Owner Name: David Bundy

Environmental Health Septic/Well Permit Diagram

Building permits cannot be issued nor should construction begin without Construction Authorization issuance.

☒ Septic Improvement Permit ☒ Septic Construction Authorization (CA) ☐ CA Reissue** ☒ As Built
☐ Well Construction Authorization ☐ Additional Diagram/Specifications Attached

Diagram Date**: 11-16-21 EHS: Joel Bender

**Any previously dated CA diagram is revoked and/or invalid. Confirm this is the valid diagram for the site before beginning any construction.

Installation/grouting inspections may be scheduled the day before, or, the day of installation until 9am by contacting the Environmental Health office at 919 496 8100. A revisit fee may apply if installation is not ready for inspection at the time requested. Septic Operations Permits will be issued after installation is approved, all permit conditions are met, and any outstanding fees are paid. Well Certificate of Completion will be issued after well head approval, all permit conditions are met, and any outstanding fees are paid.

Septic Tank 1000 Pump Tank N/A Drainfield 3'x300' Type System ACC Max Trench Depth 24"
Septic Contractor DB+Sons Septic/Pump tank dates PT DB 1000 ST DB 1000 Pump fee? Yes No \$0.00 8/26
Well Contractor _____ Well Grout date: _____

*Refer to plot plan also

300' EZ Flow
vid tanks, drain line,
pump if floods, d alarm
6-24-25
*NEED TO PAY *
PUMP FEE 1500*

House
*Has basement
- pump system
required

