

FRANKLIN COUNTY HEALTH DEPARTMENT

PERMIT NUMBER: 14945C CONST IMPROVE PERMIT 20010208	DATE: 34089	SIZE: 1.260A
APPLICANT: MITCHELL EDWARD SHANE 650 JOHN SANDLING RD FRANKLINTON NC 27525	OWNER: MITCHELL EDWARD	
TELEPHONE: 494-1041		
COMMENT: SFD	DESCRIPTION: 5 YEAR ☒	LIFETIME: ☐
LOCATION / DIRECTIONS: STONEFIELD #18 - 60 HARDWOOD DR FRK <i>Near intersection of SR 1700 + 1701</i>		
FEE: 175.00	SIGNATURE OR OWNER OR AUTHORIZED AGENT:	

THE ABOVE SIGNATURE INDICATES THAT I HAVE READ, UNDERSTAND, AND AGREE WITH ALL PROVISIONS AND INFORMATION AS OUTLINED ON THE
BACK SIDE OF THIS FORM


TOPO <u>5</u>	TEXTURE <u>PS</u>	STRUCTURE <u>PS</u>	DEPTH <u>PS</u>
R. HOR <u>5</u>	SOIL. WET <u>5</u>	AVAIL. SP <u>5</u>	OTHER <u>✓</u>
MINRL <u>5</u>	OVERALL <u>PS</u>	LTAR <u>.35</u>	
#BEDRMS <u>3</u>	GPD <u>360</u>	DISPOSAL <u>✓</u>	TYPE. SYS <u>Comm</u>
SZ. TANK <u>900</u>	SZ. CHAMB <u>✓</u>	NITRIFI <u>3'x350'</u>	TYPE. WAT <u>well</u>
SITE. LOC <u>✓</u>	MAX TRENCH DEP <u>24"</u>	TYP. FAC <u>SFD</u>	
REMARKS:	<u>Stay at least 50' from wells, 10' from property lines, 5' from foundation</u>		

Run drainlines with contour.

CONTRACTOR: Robert Blackley

TANK MANUF: Ellis 1000

MANUF DATE: 6/5/01



IMPROVEMENT PERMIT DATE: 7/8/01

CONSTRUCTION AUTHORIZATION DATE: 2/8/01

OPERATION PERMIT DATE: 7/11/01

ENV HEALTH SPEC: Kimberly Fennell

ENV HEALTH SPEC: Robert F. Fennell

ENV HEALTH SPEC: Good friend