



ESTIMATE

Shepherd's Heating and Cooling
173 Sea Foam Drive
Raleigh, North Carolina 27610
United States

9843795827

BILL TO
Dominique Lane
1418 Chatuga Way
Wake Forest, North Carolina 27587
United States

9198086323
Niquelyon@yahoo.com

Estimate Number: 3572
Estimate Date: September 8, 2025
Valid Until: October 8, 2025
Grand Total (USD): **\$834.11**

Items	Quantity	Price	Amount
Freon Leak Repair Accessible/Per Leak Freon Leak Repair Accessible/Per Leak - See Notes	1	\$209.00	\$209.00
Customized HVAC Repair Level outdoor unit.	1	\$90.00	\$90.00
Add 1-3 lb R-410A Refrigerant Add 1-3 lb R-410A Refrigerant	2	\$239.18	\$478.36
Subtotal:			\$777.36
NCSalesTAX 7.3%:			\$56.75
Grand Total (USD):			\$834.11

Notes / Terms

Upon arrival system was completely empty not having any refrigerant/vapor inside of the line set and condenser is unlevelled.
No cool due to system being empty.

We will need to run a leak search, fix leak (if in lineset), level unit and recharge system.