



OPERATION PERMIT

Franklin County Health Department
107 Industrial Drive
Louisburg, NC 27549
Phone:

For Office Use Only

*CDP File Number 458271 - 1

County ID Number:

Evaluated For: NEW

Property Owner: John Szalecki
Owner Address: 1016 Mockingbird Dr

City: Raleigh
State/Zip: NC/ 27615
Phone #:
Address: 10 Tillery Drive
Louisburg, NC 27549

Road #:
Township:
Subdivision:
Phase : NEW Lot: 2

Structure: SINGLE FAMILY

of Bedrooms: 3

of People: 6

Water Supply: NEW WELL

Saprolite System?: ☐ Yes ☒ No

Pump Required?: ☒ Yes ☐ No

Design Flow: 360

System Classification/Description: TYPE III B. SYSTEM
W/SINGLE EFFLUENT PUMP

Installer: DB & SONS

Certification #: 1036

Specific System POLYSTYRENE AGGREGATE
Installed:

STB: 502

PT: 237

Comments: 300' EZ FLOW INSTALLED

Septic Tank Date: _____

Pump Tank Date: _____

This system has been installed in compliance with applicable NC General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.

PERMIT CONDITIONS:

I. Performance: System shall perform in accordance with Rule .1301.

II. Monitoring: As required by Rule .1301.

III. Maintenance: Ground absorption sewage treatment and disposal systems shall be checked, and the contents of the septic tank removed, periodically from all compartments, to ensure proper operation of the system. The contents shall be pumped whenever the solids level is found to be more than 1/3 of the liquid depth in any compartment.

Other:

Subsurface Operator Required: ☐ Yes ☒ No

If yes, see attached sheet for additional operation conditions, maintenance and reporting.

Operation:

Other: 300' EZ FLOW INSTALLED

Authorized State Agent: Ennis, Crystal *Crystal Ennis*

Date of Issue: 12/15/2025

Owner/Applicant: _____

