

Large Layout on Back

2000

PERMIT NUMBER N2 17

GRANVILLE - VANCE DISTRICT HEALTH DEPARTMENT
IMPROVEMENT AND OPERATION PERMITS

COUNTY: Vance	TAX NO: 6379 03017	TYPE OF ESTABLISHMENT			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.
OWNER: Joseph A. Davis	SER. NO. 1329	RESIDENCE ☒ BUSINESS ☐ OTHER ☐	NUMBER OF BEDROOMS: 3	NUMBER OF OCCUPANTS: 1	
APPLICANT: Joseph A. Davis		WATER SUPPLY			
APPLICANT'S ADDRESS: 27536 2691 Mc 39th Henderson		PUBLIC ☐	WELL ☒	OTHER ☐	
PROPERTY ADDRESS/LOCATION: Stagecoach Rd		TYPE OF WASTEWATER SYSTEM			*THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED.
		DESCRIPTION	INITIAL ☒ INSTALLATION	REPAIR	
SUBDIVISION:		DESIGN FLOW:	360 gal/day		
LOT NUMBER: A		LTAR:	3		
REFERENCE SKETCH (SEE PLAT FOR DETAILS) See sketch on back. Dig trenches 18"-24" deep (level) on contour! Stay at least 5' from house, 10' from property line, + 100' from any well. Do not install or call for inspection in 2000. Must pump to repair		ABSORPTION AREA:	1200 sq. ft.		
		TRENCH WIDTH:	3'		
		TRENCH SPACING:	9' on center		
		TOTAL TRENCH LENGTH:	400 ft.		
		NUMBER OF TRENCHES:	5 @ 80' each		
		GRAVEL DEPTH:	12"		
		TANK SIZE:	1000 gal.		
		CONDITIONS:			
IMPROVEMENT PERMIT		DATE:			
FOR: Joseph A. Davis III		2/17/99			
ISSUED BY: M.E. Young R.S.					
OPERATION PERMIT		DATE:			
SYSTEM INSTALLED BY: Fleddie Williams		12-9-99			
ISSUED BY: W. King					