

774 GRANVILLE-VANCE HEALTH DEPARTMENT—Sewage Disposal Record

Owner or Contractor Robert & Nancy Woodlief Date 1-6-88 S.R. No. 1102
 Location/Address Rt. 2 Creedmoor, N.C.
 Subdivision/Mobile Home Park Name 1718 W. 11 St. H Rd. Lot Size 5Ac.
 Lot No. _____

New System ☒ Repair _____
 House ☒ Mobile Home _____ Business _____
 No. Bedrooms 3 No. People 4 No. Toilets 2
 Water Supply: Private ☒ Approved _____
 Semi-Public _____ Unapproved _____
 Public _____ None _____

Layout to be followed by installer:

Nitrification System:

Tank Size 900 gal.
 Distribution Box 46 No. Lines 2
 Nitrification Field 320' - 960 Sq. Ft.
 Lines: 1 2 3 4 5 6
 Width 3' 3' _____
 Length 160' 160' _____
 Grade 1" level _____
 Stone Depth 12" 12" _____

Improvements Permit By Bobby E. Greene Installer Wm. Hight
 Certificate of Completion By CK Nollin Date of Inspection 4-26-88

* Construction must comply with all other applicable state and local regulations, but the permit is a guarantee that the system will not malfunction and the Granville-Vance Health District will not be held responsible for a malfunctioning system.

NOTE: Make sketch of installation showing location of house, septic tanks, privies, water supplies on adjacent property, etc. Write in measurements in order that installations may be located at later date.

