

**Franklin County Health Department
Environmental Health Section
107 Industrial Drive-Suite C
Louisburg, North Carolina 27549**

Phone: 919-496-8100

Fax: 919-496-8136

Permit Number: 2359 Type: I PIN: 1889-63-5385 Date: 3/2/2006

Applicant: CHRISTOPHER & SUSAN BELVAL Owner: SHERIAN EPSTEIN
7547 NC HWY 86 S 245 DREAMCATCHER TRAIL
YANCEYVILLE, NC 27379 YOUNGSVILLE, NC 27596

Telephone: (336) 504-9588

Telephone: 1-336-504-9588

Subdivision:

Lot Number:

Size: 7,800

Physical Address/ Location /Directions

Description: LifeTime _____ 5 Year ✓

TYPE FACIL Res # EMPLOY — # BEDRMS 5 GPD 600 LTAR .39^{pd}/ft²
 TYPE WAT Priv TYPE SYS 4th TYPE REP C BSMT NO BST FX —
 SIZE TANK 1200 SIZE CHB — SIZE NITR 3'x⁵⁰⁰6'10" MTD 22"

COMMENTS Install lines on contour and in dry conditions.
Do not exceed MTD of 22". May use
500' accepted product.

Septic Contractors are responsible for notifying the health department for final inspections, between 8:00-9:00 AM on the day of completion, Monday - Friday. Any request for final inspections received afterwards will be scheduled the same day, if possible, or the next workday. Have permit number and owner/applicant's name ready when making the call.

Actions of representatives of state or local agencies engaged in the evaluation and determination of measures required to effect the compliance with the provisions of this permit shall in no way be taken as a guarantee that wastewater disposal systems permitted and approved will function in a satisfactory manner for any given period of time, or that such employees assume any liability for damages, consequential or direct which are caused, or may be caused, by a malfunction of this wastewater treatment and disposal system.

Proper precautions must be taken to assure the proper functioning of the system after it has been covered. Do not run any heavy equipment over the system, as soft earth will allow damage to the tank and lines. Pipe all roof drains away from the septic system site to prevent flooding of the lines from surface water. Terrace the ground to prevent excessive drainage from higher areas adjacent to the system. Do not construct driveways over any part of the septic system unless proper provisions were made when the septic system was constructed. Only grass, not trees or shrubbery, should be cultivated over the lines. All plumbing fixtures should be carefully inspected periodically and any problems repaired immediately. All septic tanks should be pumped off by a permitted pump operator on a regular schedule, not to exceed every five years.

The improvement permit and construction authorization is a site approval, for the future installation of a wastewater treatment and disposal system. Changes in ownership of the site do not affect the validity of this permit. However, any alteration of the site or soil conditions, changes in the location of the proposed facility, changes to the wastewater flow and/or characteristics, or submittal of false information with the application or misrepresentation of the property lines may subject this permit to suspension or revocation.

**FOR THIS TO BE A VALID CONSTRUCTION AUTHORIZATION, A LAYOUT SHEET MUST BE
ATTACHED**

IMPROVEMENT PERMIT

DATE 8-8-06 EHSRenee Shear

CONSTRUCTION AUTHORIZATION

DATE 8-8-06 EHSRenee Shear

Franklin County Health Department


Name: BELVAL

Permit Number

2359

CONTRACTOR James Madden TANK MANU GCP 1250 MANU DATE 4-12-06WELL INSTALLED YES ✓ NO SYSTEM CODE EZ1203T-N-G

SEPTIC SYSTEM LAYOUT (SKETCH SYSTEM LAYOUT HERE)



SEPTIC SYSTEM AS-BUILT

(IF DIFFERENT FROM INITIAL LAYOUT)

ON REVERSE

OPERATIONS PERMIT

DATE 11-29-06 EHSRenee Shearin

FRANKLIN COUNTY SOIL/SITE EVALUATION SHEET

APPLICANT Chris Belval
 WATER SUPPLY Private
 LOCATION/DIRECTIONS J.A. Rogers Rd

PROPERTY ID _____
 DATE 3-9-06

FACTORS

PROFILES

		1	2	3	4	5	6
LANDSCAPE POSITION	1940	SS	SS				
SLOPE (%)	1940	4%	2%				
HORIZON I DEPTH	1943	0-2	0-2				
TEXTURE	1941(a) (1)	SL	SL				
CONSISTENCE	1941	vfr, ns, np	vfr, ns, np				
STRUCTURE	1941(a)(2)	gr	gr				
CLAY MINEROLOGY	1941(a)(3)	SEXP	SEXP				
HORIZON II DEPTH	1943	2-36"	2-10"				
TEXTURE	1941(a) (1)	C	SCL				
CONSISTENCE	1941	fi, fr, ss, sp	fr, ss, np				
STRUCTURE	1941(a)(2)	sbk	cr				
CLAY MINEROLOGY	1941(a)(3)	SEXP	SEXP				
HORIZON III DEPTH	1943		10-36"				
TEXTURE	1941(a) (1)		C				
CONSISTENCE	1941		fi, ss, sp				
STRUCTURE	1941(a)(2)		sbk				
CLAY MINEROLOGY	1941(a)(3)		SEXP				
HORIZON IV DEPTH	1943		36-42"				
TEXTURE	1941(a) (1)		CL				
CONSISTENCE	1941		vfr, ss, np				
STRUCTURE	1941(a)(2)		cr				
CLAY MINEROLOGY	1941(a)(3)		SEXP				
SOIL WETNESS	1941	> 36"	> 42"				
RESTRICTIVE HORIZON	1944	> 36"	> 42"				
SAPROLITE	1943/1956	36"	> 42"				
CLASSIFICATION	1948	PS	PS				
LTAR (gpd/ft2)	1955	.3	.3				
OTHER FACTORS (1946)			SITE LTAR (gpd/ft2) .3				
AVAILABLE SPACE (1945) S			SYSTEM TYPE Conventional				
CLASSIFICATION (1948) PS							
EVALUATED BY: Renee Sheari			OTHERS PRESENT NONE				

COUNTY OF FRANKLIN
ENVIRONMENTAL HEALTH APPLICATION (496-8100)

Permit #: **17192**

Permit Type: **SEPTIC PERMIT**

Date Issued: **03/01/2006**

Project Address: ,

Location:

Size #: **7.800**

Subdivision:

Lot #:

Applicant: **BELVAL CHRISTOPHER & SUSAN**
7547 NC HWY 86 S
YANCEYVILLE NC 27379

Phone: **336.504.9588**

Owner: **EPSTEIN SHERIAN**
245 DREAMCATCHER TRL
YOUNGSVILLE NC 27596

Phone:

Tax record: **38314**

Pin #: **1889-63-5385**

Parcel #: **F02 00 027C**

Zoned: **A R**

Setbacks Front: **30**

Rear: **25**

Side: **10**

Proposed Use: **SFD**

of bedrooms: **5**

of people: **3**

Township: **HAYESVILLE**

Public Water/Sewer: **PRIVATE**

ST Road #:

Desc:

Fees Due: **\$275.00**

Date Paid: **03/01/2006**

*** Please complete all sections below***

☐ Yes ☒ No Does this site contain any previously identified jurisdictional wetlands?
☐ Yes ☒ No Is any wastewater, other than domestic, going to be generated?
☐ Yes ☒ No Is the site subject to approval by any other public agency?

*If the answer to any of the above is "yes", applicant must submit supporting documentation.

Please indicate desired system type(s). Systems can be ranked in order of preference.

☒ Conventional ☐ Alternative ☐ Innovative ☐ Modified Conventional
☐ Other ☐ No Preference

Call Environmental Health (919.496.8100) between 8:00 - 9:00 am Monday - Friday in order to schedule an appointment with an environmental health specialist for your lot evaluation. This application for an improvement permit/construction authorization does not constitute approval for zoning, septic or building permits. It will be necessary to meet all guidelines for zoning, septic and building permits prior to construction. The permit is valid for either 60 months or without expiration, depending upon documentation submitted. (complete site plan= 60 months---complete surveyed plat=without expiration.)

I hereby certify that I am the owner, or authorized by the owner to act as his/her legal representation. Furthermore, as legal representative (if applicable) I have advised the owner of my intention to apply for this wastewater treatment and disposal system.

I also certify that all of the statements made in this application and any attached documents are true, complete, and correct, to the best of my knowledge and belief, and are made in good faith. If information in application for improvement permit is falsified, changed or site is altered, then improvement permit and authorization to construct shall become invalid. Authorized county representatives are granted right of entry to make evaluations or inspections, and to release information upon public request.

X Susan Taft-Belval Susan Taft-Belval
Print & Signature of Owner or Owner's Legal Representative

03/01/2006

2359

COUNTY OF FRANKLIN

ENVIRONMENT HEALTH APPLICATION (496-8100)

Permit #: **17192**

Permit Type: **SEPTIC PERMIT**

Date Issued: **03/01/2006**

Project Address: ,

Location:

Size #: **7.800**

Subdivision:

Lot #:

Applicant: **BELVAL CHRISTOPHER & SUSAN**
7547 NC HWY 86 S
YANCEYVILLE NC 27379

Phone: **336.504.9588**

Owner: **EPSTEIN SHERIAN**
245 DREAMCATCHER TRL
YOUNGSVILLE NC 27596

Phone:

Tax record: **38314**

Pin #: **1889-63-5385**

Parcel #: **F02 00 027C**

Zoned: **A R**

Setbacks Front: **30**

Rear: **25**

Side: **10**

Proposed Use: **SFD**

of bedrooms: **4**

of people: **3**

Township: **HAYESVILLE**

Public Water/Sewer: **PRIVATE**

ST Road #:

Desc:

Fees Due: **\$275.00**

Date Paid: **03/01/2006**

*** Please complete all sections below***

☐ Yes ☒ No Does this site contain any previously identified jurisdictional wetlands?
☐ Yes ☒ No Is any wastewater, other than domestic, going to be generated?
☐ Yes ☒ No Is the site subject to approval by any other public agency?

*If the answer to any of the above is "yes", applicant must submit supporting documentation.

Please indicate desired system type(s). Systems can be ranked in order of preference.

☒ Conventional ☐ Alternative ☐ Innovative ☐ Modified Conventional
☐ Other ☐ No Preference

Call Environmental Health (919.496.8100) between 8:00 - 9:00 am Monday - Friday in order to schedule an appointment with an environmental health specialist for your lot evaluation. This application for an improvement permit/construction authorization does not constitute approval for zoning, septic or building permits. It will be necessary to meet all guidelines for zoning, septic and building permits prior to construction. The permit is valid for either 60 months or without expiration, depending upon documentation submitted. (complete site plan= 60 months---complete surveyed plat=without expiration.)

I hereby certify that I am the owner, or authorized by the owner to act as his/her legal representation. Furthermore, as legal representative (if applicable) I have advised the owner of my intention to apply for this wastewater treatment and disposal system.

I also certify that all of the statements made in this application and any attached documents are true, complete, and correct, to the best of my knowledge and belief, and are made in good faith. If information in application for improvement permit is falsified, changed or site is altered, then improvement permit and authorization to construct shall become invalid. Authorized county representatives are granted right of entry to make evaluations or inspections, and to release information upon public request.

X Susan Taft-Belval Susan Taft-Belval
Print & Signature of Owner or Owner's Legal Representative

03/01/2006

Franklin County DRC Application

RESIDENTIAL

Zoning Permit #: 10376



ADDRESS:

PARCEL NO.: 1889-63-5385

ZONING: A R

SUBDIVISION:

ISSUED TO: BELVAL CHRISTOPHER & SUSAN

7547 N C HWY 86 S

YANCEYVILLE NC 27379

PHONE NUMBER: 336 504-9588

SETBACK: FRONT: 30 RIGHT: 10 LEFT: 10 REAR: 25

COUNTY WATER: N/A FLOODPLAIN: N/A

PERMIT TYPE: ZONING PERMIT

TYPE OF CONSTRUCTION: SFD

PERMIT DATE: 03/01/2006 WATERSHED IV

TOWNSHIP HAY EXPIRE DATE: / /

It is hereby certified that the above use as shown on the plats and plans submitted with this application conforms with all applicable provisions of the Franklin County Zoning Ordinance. The issuance of this application does not allow the violation of Franklin County Zoning Ordinance or other governing regulations. The applicant is responsible for obtaining a building permit (if required) prior to commencing work on the proposed improvement. A final zoning inspection must be scheduled by the applicant.

NOTES:

I hereby certify that all information I have provided to the Planning Department is true and accurate.

APPLICANTS SIGNATURE:

Susan Jeff-Belval

UTILITY COMPANY : PROGRESS ENGERY

WAKE ELECTRIC

OTHER

NUMBER OF STORIES: 1 _____ 1 1/2 _____ 2 _____ 2 1/2 _____

SQUARE FOOTAGE: HEATED _____ UNHEATED _____ TOTAL _____

BASEMENT: N/A _____ YES _____ NO _____ MANUFACTURED _____

FIREPLACE: N/A _____ MASONARY _____ MANUFACTURED _____

PLAN SETS: MODULAR _____ SURETY BOND _____ STICKBUILT _____

NAME OF:

ELECTRICIAN: _____ MECHANICAL: _____

PLUMBING: _____

COST OF CONSTRUCTION: _____

NO MORE THAN 2 STRUCTURAL DEVIATIONS OR PLANS MUST BE REDRAWN

DEPARTMENTAL USE ONLY

	INITIALS (IN)	DATE	INITIALS (OUT)	DATE
ZONING	<i>DPW</i>	<i>3-1-06</i>	_____	_____
INITIAL PERMITTING	_____	_____	_____	_____
ADDRESSING	_____	_____	_____	_____
PLAN REVIEW	_____	_____	_____	_____
FIRE REVIEW	_____	_____	_____	_____
SEPTIC/SEWER	_____	_____	_____	_____
FINAL PERMITTING	_____	_____	_____	_____

with my free consent, I certify that the minimum building lines, and dedicate all drainageways and other open space to public or private use as noted. Further, I certify that the land as shown hereon is within the Subdivision Regulation Jurisdiction of Franklin County.

JOHN A. ROGERS
D.B. 745, Pg. 284
TRACT # 1

Owner _____ Date _____

JOHN A. ROGERS
D.B. 745, Pg. 284
TRACT # 2

TIE
S 20°39'01"E
942.17'

S.R. 1240 - J.A. ROGERS ROAD

TIE
N 78°37'33"E
150.42'

TIE
N 05°14'26"E
9.38'

N 78°37'33"E
150.42'

RENEE E. BENNETT
D.B. 1017, Pg. 997
PRF. 3, SLIDE 92-256

7.796 ACRES
D.B. 1017, Pg. 997
ZONING: A R

M. WANDA HENDERSON
D.B. 864, Pg. 748

CURVE	RADIUS	TANGENT	LENGTH	DELTA	CHORD	CH. BEARING
C-1	300.00'	70.37'	138.23'	26°24'02"	137.01'	N 65°25'32"E

I certify that this survey creates a subdivision of land within the area of a county or municipality that has an ordinance that regulates parcels of land.

Robert C. Cawthorne
Robert C. Cawthorne, P.L.S. L-3961



CAWTHORNE &
Registered Land

P. O. Box 1558
Henderson, North Carolina
Phone # 252-492-0041