

Nav Zoning Model

Robert Blackley
Friday July 15th
Before lunch
PERMIT NUMBER 4452

GRANVILLE-VANCE DISTRICT HEALTH DEPARTMENT
IMPROVEMENT AND OPERATION PERMITS

COUNTY:	TAX NO.	TYPE OF ESTABLISHMENT			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.
Granville	152500322289	RESIDENCE ☒	NUMBER OF BEDROOMS:	NUMBER OF OCCUPANTS:	
OWNER: Wynn Construction	SR. NO. 1096	BUSINESS ☐	3	5pc	
APPLICANT: Same		WATER SUPPLY			*THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED.
APPLICANT'S ADDRESS: 1696 Hayes Pl. Columbus		PUBLIC ☐	WELL ☒	OTHER ☐	
PROPERTY ADDRESS/LOCATION: Ashton Glen Lane		TYPE OF WASTEWATER SYSTEM			
		DESCRIPTION	INITIAL INSTALLATION	REPAIR	*THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USES CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
SUBDIVISION: Ashton Glen		DESIGN FLOW:	360 gpd/day	(Innovative)	
LOT NUMBER: 8		LTAR:	3 gal/day/ft ²		
REFERENCE SKETCH (SEE PLAT FOR DETAILS) *See attached page for layout lines dug level and on contour, trench depth 18"-24" Stub-out for tank as shown!! →		ABSORPTION AREA:	1200 ft ² → 900 ft ²		
		TRENCH WIDTH:	3'		
		TRENCH SPACING:	9' o.c.		
		TOTAL TRENCH LENGTH:	*300'		
		NUMBER OF TRENCHES:	3 or 4		
		GRAVEL DEPTH:	Innovative Product		
		TANK SIZE:	1000 gal + 10'-Box		
		CONDITIONS: *	See Authorization to Construct		
IMPROVEMENT PERMIT				DATE:	
FOR: Wynn Construction ISSUED BY: David Pembree RS				5-24-05	
OPERATION PERMIT				DATE:	
SYSTEM INSTALLED BY: Robert Blackley				7-15-05	
ISSUED BY: M.E. Mount, RS					