

OWNER Meadow, Phil ADDRESS Oxford Rd
 OCCUPANT 0426 A04004 SUBDIVISION Hunters Ridge
 HOUSE ☒ MOBILE HOME ☐ BUSINESS ☐ LOT AREA LOT # 17
 SEPTIC TANK: (SIZE 1600 GALS.) PRIVY: (NUMBER)
 No. Bedrooms 3 No. Bathrooms 2 New Date
 Garbage Disposal Unit Yes ☐ No ☒ Repaired Date
 Auto. Dishwasher Yes ☒ No ☐
 Auto. Wash. Machine Yes ☒ No ☐
 Nitrification Field 900 sq. ft. WATER SUPPLY:
 Depth of stone in lines 12 Individual ☒ Public ☐
 If well, type:
 Bored ☒ Drilled ☐ Dug ☐
 Distance from nearest pollution Ft.
 FARMERS HOME ADM. CASE # REMARKS: Separate System
 Contractor Otis Parham 75' of line for
 Address Oxford dishwasher & wash machine
 PERMIT # 870 DATE 6-3-77
 APPROVED: YES ☒ NO ☐
 APPROVED BY: DW

DHS Form 1106 Rev. 2/75
Sanitation

SEWAGE DISPOSAL RECORD

GRANVILLE-VANCE HEALTH DISTRICT No 870 (Septic Tank) Improvements Permit and Certificate of Completion

Owner or Contractor Phil Meadow (Joe Bryn) Date 3-8-77 S.R. No.

Location Hunters Ridge

Subdivision Name Lot No. Section or Block No.

New System ☒ Repairs ☐

House ☒ Mobile Home ☐ Business ☐

No. Bedrooms 3 No. In Family

No. Bathrooms

Garbage Disposal Yes ☐ No ☒

Auto. Dishwasher Yes ☒ No ☐

Auto. Wash. Machine Yes ☒ No ☐

Water Supply: Individual ☐ Public ☒

Nitrification System: Tank Size 1000 Gal.

Distribution Box yes

Nitrification Field 900 Sq. ft.

Nitrification Lines: 300 Length

3' Width 2 No.

Lot: area 1.07 acre length width

12 inches stone

ditches 40" deep minimum

separate line 50'-100'

for dishwasher & washer

12" stone

Improvements Permit By Joe Winder Installed By Otis Parham

Certificate of Completion By Joe Winder Date 6-3-77

* Construction must comply with all other applicable state and local regulations, but the permit is not a guarantee that the system will not malfunction and the Granville-Vance Health District will not be held responsible for a malfunctioning system.