

Large Layout on Back

3

Louisville
 SR. NO. 5789113
 M 965
 OWNER: Wyna Contracting
 APPLICANT'S ADDRESS:
 1695 Hays, Road
 Creedmoor, NC 27522
 5th Lane Drive
 PROPERTY ADDRESS/LOCATION: off
 M 965
 SUBDIVISION:
 Heritage Hall
 LOT NUMBER: 20
 REFERENCE SKETCH (SEE PLAT FOR
 DETAILS) See sketch on back.
 Dig trenches 18"-24" deep
 and on contour. Stay
 at least 10' from
 foundation drain, 10'
 from property line
 - 100' from any well
 Do not install so call
 for inspection to drain

DATE: 3-28-07

ISSUED BY: M. E. Young RS

Unless otherwise indicated, the same conditions above apply regarding system type, layout, location and installation requirements.
(The wastewater system cannot be installed until authorization is signed)

Date: 3-28-07 Environmental Health Specialist: M.E. Yount R1
Construction Authorization Addendum ☐ Yes ☒ No

DATE: _____

PERFORMANCE, MONITORING, MAINTENANCE AND OPERATION
AS REQUIRED BY RULE 1961

