


Thurs. 3:00 P.M. June 18th

PERMIT NUMBER Nº

044

GRANVILLE - VANCE DISTRICT HEALTH DEPARTMENT
IMPROVEMENT AND OPERATION PERMITS

COUNTY:	TAX NO.	TYPE OF ESTABLISHMENT			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.	
Granville	SIR NO. 1705	RESIDENCE ☒	NUMBER OF BEDROOMS: 3	NUMBER OF OCCUPANTS: For sale		
OWNER: D.B. Williams Court		BUSINESS ☐				
APPLICANT: Same	WATER SUPPLY				*THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED.	
APPLICANT'S ADDRESS:	PUBLIC ☐	WELL ☒	OTHER ☐			
PROPERTY ADDRESS/LOCATION:	TYPE OF WASTEWATER SYSTEM			DESCRIPTION		
Granville Co. SR 1705						INITIAL INSTALLATION
SUBDIVISION: Evans Ridge	DESIGN FLOW:	120 X 5				REPAIR
LOT NUMBER: 9	LTAR:	.4				
REFERENCE SKETCH (SEE PLAT FOR DETAILS)	ABSORPTION AREA:	900				*THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USE CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
	TRENCH WIDTH:	3'				
	TRENCH SPACING:	9'00				
	TOTAL TRENCH LENGTH:	200'				
	NUMBER OF TRENCHES:	2				
	GRAVEL DEPTH:	18"				
	TANK SIZE:	900 Dist. 600				
	CONDITIONS:					
IMPROVEMENT PERMIT				DATE:		
FOR: D.B. Williams Court				3-27-96		
ISSUED BY: Charles R. Noflin				DATE:		
OPERATION PERMIT				DATE:		
SYSTEM INSTALLED BY: Ricky Pearce (Union County)				10-19-96		
ISSUED BY: Chris Hall						



GRANVILLE-VANCE HEALTH DEPARTMENT—Sewage Disposal Record

Owner or Contractor PB Williams Construction Date 5-27-96 S.R. No. 1705

Location/Address Old Franklin Rd - Grandblain

Subdivision/Mobile Home Park Name Evans Ridge Lot Size 1.0 Acre

Permit No. # 044 Lot No. 9

New System ☒ Repair ☐

House ☒ Mobile Home ☐ Business ☐

No. Bedrooms 3 No. People FS No. Toilets

Water Supply: Private ☒ Approved ☐

Semi-Public ☐ Unapproved ☐

Public ☐ None ☐

Nitrification System:

Tank Size 900 gal.

Distribution Box ☒ No. Lines 2

Nitrification Field 900 Sq. Ft.

Lines:	1	2	3	4	5	6
Width	<u>3'</u>	<u>3'</u>				
Length	<u>91'</u>	<u>105'</u>				
Grade	<u>1/2"</u>	<u>1/2"</u>				
Stone Depth	<u>18"</u>	<u>18"</u>				

Layout to be followed by installer:

Improvements Permit By Charles R. Noflin Installer Ricky Perce (Vance Co)

Certificate of Completion By Chris Hildebrand Date of Inspection 6-13-96

* Construction must comply with all other applicable state and local regulations, but the permit is not a guarantee that the system will not malfunction and the Granville-Vance Health District will not be held responsible for a malfunctioning system.

NOTE: Make sketch of installation showing location of house, septic tanks, privies, water supplies on adjacent property, etc. Write in measurements in order that installations may be located at later date.

* Powell

