

GRANVILLE-VANCE HEALTH DISTRICT

No 0698

(Septic Tank) Improvements Permit & Certificate of Completion

Owner or Contractor Jack Greene Date 3-8-88 S.R. No. _____

Location/Address Off Northway Bridge Rd. 1080 Hedrick Dr

Subdivision/Mobile Home Park Name Kerr Lake Estates Lot Size 1 ac

35 Lot No. (2 lots)

New System ☒ Repair _____

House ☒ Mobile Home _____ Business _____

No. Bedrooms 3 No. People 2 No. Toilets 2

Water Supply: Private ☒ Approved _____

Semi-Public _____ Unapproved _____

Public _____ None _____

Nitrification System:

Tank Size 1000 gal.

Distribution Box yes No. Lines 3-3204

Nitrification Field 460 Sq. Ft.

Lines: 1 2 3 4 5 6


Width 3' 3' 3' _____

Length 110' 110' 100' _____

Grade _____

Stone Depth 18" 18" 18" _____

Layout to be followed by installer:



Improvements Permit By [Signature] Installer David King

Certificate of Completion By [Signature] Date of Inspection 1-4-88

* Construction must comply with all other applicable state and local regulations, but the permit is not a guarantee that the system will not malfunction and the Granville-Vance Health District will not be held responsible for a malfunctioning system.