

PUMP TO CONVENTIONAL - ORIGINAL & REPAIR

PERMIT NUMBER **3724**

GRANVILLE-VANCE DISTRICT HEALTH DEPARTMENT IMPROVEMENT AND OPERATION PERMITS

COUNTY: VANCE	TAX NO. 0354C01021	TYPE OF ESTABLISHMENT			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.
OWNER: T & W INVESTMENTS	SR. NO.	RESIDENCE ☒ BUSINESS ☐ OTHER ☐	NUMBER OF BEDROOMS: 43	NUMBER OF OCCUPANTS: ≤ 8	
APPLICANT: W.A. CURRIN		WATER SUPPLY			
APPLICANT'S ADDRESS:		PUBLIC ☐	WELL ☒	OTHER ☐	
PROPERTY ADDRESS/LOCATION: 50 TYLER CT.		TYPE OF WASTEWATER SYSTEM			*THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED.
		DESCRIPTION	INITIAL INSTALLATION	REPAIR	
SUBDIVISION: SOMERSET		DESIGN FLOW:	450 gal/day		
LOT NUMBER: 21+21A .74645		LTAR:	0.3		
REFERENCE SKETCH (SEE PLAT FOR DETAILS) * SEE ATTACHED LAYOUT		ABSORPTION AREA:	1200 1600 FT²		
		TRENCH WIDTH:	3'		
		TRENCH SPACING:	AT LEAST 4' ON CENTERS		
		TOTAL TRENCH LENGTH:	400 534'		
		NUMBER OF TRENCHES:	4-5		
		GRAVEL DEPTH:	12"		
		TANK SIZE:	1000 GAL SEPTIC TANK 1000 GAL PUMP TANK		*THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USES CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
		CONDITIONS:	24" TRENCH DEPTH		
IMPROVEMENT PERMIT FOR: T & W INVESTMENTS ISSUED BY: Paul L. Young				DATE: 10-24-03	PERMIT VALID FOR 5 YEARS FROM DATE OF ISSUE
OPERATION PERMIT SYSTEM INSTALLED BY: Cole Backhoe Service ISSUED BY:				DATE:	

* Inspected nitrification lines only 10-6-04, mds