

IMPROVEMENT PERMIT

Granville Vance Public Health

Environmental Health

PO Box 367

Oxford, NC 27565

Phone: (252) 492-5263 Fax: (252) 492-2361

File/Permit Number: 356456 - 1

PIN/Lot Identifier: 097201263707

Evaluated For: NEW

Permit valid until: 05/14/2026

The issuance of this permit in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. The Department and Local Health Department may impose conditions on the issuance and may revoke the permits for failure of the system to satisfy the conditions, the rules, or this article. This permit is subject to revocation if the site plan, plat, or intended use changes (NCGS 130A-335(f)). The person owning or controlling the system shall be responsible for assuring compliance with the laws, rules, and permit conditions regarding system location, installation, operation, maintenance, monitoring, reporting, and repair rule .0301(a)).

IMPROVEMENT PERMIT

Granville Vance Public Health
Environmental Health
PO Box 367
Oxford, NC 27565
Phone: (252) 492-5263 Fax: (252) 492-2361

File/Permit Number: 356456 - 1
PIN/Lot Identifier: 097201263707
Evaluated For: NEW
Permit valid until: 05/14/2026

Applicant: Latasha S. Drake Owner's Phone Number: _____
Owner: Anthony Struzziery
Property Location: 1401 Black Farm Rd Rougemont, NC 27572
Road#: _____
Subdivision (if applicable): _____
Lot Size: 3.00 Lot #: 8 Block: _____ Section: _____
Facility Type: SINGLE FAMILY Number of bedrooms: 5
Proposed Designed Daily Flow(GPD): 600 Number of Occupants: 5
Type of Water Supply: NEW WELL Other: _____

System Specifications Initial

Proposed Wastewater System Type*: 25% REDUCTION
**Please include system classification for proposed wastewater system types in accordance with Rule .1301 Table XXXII*
Proposed LTAR: 0.275 Saproliote System: No Septic Tank (gallons): 1200
Usable depth to Limiting Condition (inches): _____ Min. Trench Depth (inches)*: 18
Fill Depth: _____ Max. Trench Depth (inches)*: 20
Pump required: No Pump Tank(Gallons): 1,200 **Measured on the downhill side of the trench*

System Specifications Repair

Repair System Required: Yes
Proposed Wastewater System Type*: TYPE III G. OTHER NON-CONV. TRENCH SYSTEMS
**Please include system classification for proposed wastewater system types in accordance with Rule .1301 Table XXXII*
Proposed LTAR: 0.275 Saproliote System: No
Usable depth to Limiting Condition (inches): _____ Min. Trench Depth (inches)*: 18
Fill Depth: _____ Max. Trench Depth (inches)*: 20
Pump required: No **Measured on the downhill side of the trench*

Artificial Drainage Required: No If yes, please details: _____
Drainfield location meets requirements of Rule .0508: No Drainfield location meets requirements of Rule .0601: No

Permit Conditions:

Site Modifications: House location will need to move towards Range Road. Lot will need to be cleared before construction authorization is issued.

Permit Conditions: # of bedrooms and layout will be determined after lot is cleared.

Authorized Agent's Printed Name: _____ Issue Date: 05/14/2021
Authorized Agent's Signature: _____ Date: 05/14/2021

See attached site sketch