


FRANKLIN COUNTY HEALTH DEPARTMENT

PERMIT NUMBER: 78870 CONST IMPROVE PERMIT		DATE: 03.20.96	21587	SIZE:
APPLICANT: LLOYD LONNIE 918 DE VINCI ST DURHAM NC 27704 TELEPHONE: 598-3643		OWNER: LLOYD LONNIE 918 DE VINCI ST DURHAM NC 27704		
COMMENT:				
LOCATION / DIRECTIONS: LAKE ROYALE #2845 behind carriage minor				
FEE: 100.00 1739		SIGNATURE OR OWNER OR AUTHORIZED AGENT:		

THE ABOVE SIGNATURE INDICATES THAT I HAVE READ, UNDERSTAND, AND AGREE WITH ALL PROVISIONS AND INFORMATION AS OUTLINED ON THE BACK SIDE OF THIS FORM

TOPO <u>PS</u>	TEXTURE <u>PS</u>	STRUCTURE <u>-</u>	DEPTH <u>-</u>
R. HOR <u>-</u>	SOIL. WET <u>-</u>	AVAIL. SP <u>-</u>	OTHER <u>-</u>
MINRL <u>NEP</u>	OVERALL <u>PS</u>	LTAR <u>.4%</u>	
#BEDRMS <u>3</u>	GPD <u>360^{gpd}</u>	DISPOSAL <u>-</u>	TYPE. SYS <u>C</u>
SZ. TANK <u>900</u>	SZ. CHAMB <u>3x3</u>	NITRIFI <u>3x300</u>	TYPE. WAT <u>Comm</u>
SITE. LOC <u>-</u>	MAX TRENCH DEP <u>1</u>	TYP. FAC <u>SFD</u>	

REMARKS: Shallow system 5' from property line, land 5' from building foundation. 15' drop downs will be needed follow contour as close as possible



IMPROVEMENT PERMIT DATE: <u>4/7/96</u>	ENV HEALTH SPEC: <u>Huffery Wood</u>
CONSTRUCTION AUTHORIZATION DATE: <u>4/7/96</u>	ENV HEALTH SPEC: <u>Huffery Wood</u>
OPERATION PERMIT DATE: <u>Done Actn 10/23/96</u>	ENV HEALTH SPEC: <u>Done Actn</u>