


FRANKLIN COUNTY HEALTH DEPARTMENT

PERMIT NUMBER: AGGREGATE IMPROVEMENTS PERMIT	DATE: 04.01.93	26796	SIZE: 1.54A
APPLICANT: GARRISON KYLE & TRACY 104 PINEVIEW DR LOUISBURG NC 27549 TELEPHONE: 365-5000		OWNER: ACE IMENTERPRISES	
COMMENT: MOBILE HOME		CONTRACTOR: Vernon Dickerson	
LOCATION / DIRECTIONS: DUNN- NONORTH POINT IV 341717 72 into S/D T/K - T 7th left hand.			
FEE: 58 6307		SIGNATURE OF OWNER OR AUTHORIZED AGENT:	

THE ABOVE SIGNATURE INDICATES THAT I HAVE READ, UNDERSTAND, AND AGREE WITH ALL PROVISIONS AND INFORMATION AS OUTLINED ON THE BACK SIDE OF THIS FORM

#BEDRMS 3 DISPOSAL NO OTHER - TYPE.SYS C
 SZ.TANK 900 SZ.CHAMB - NITRIFI 3x350' OPER.REG NO
 SITE.LOC -

REMARKS: Keep system separate - 44" x 1" max! 1/2" in center of lot. 100' from well & 10' from deep line



DATE ISSUED <u>4-7-93</u>	EH SPECIALIST <u>Chris Holby R 2</u>
DATE APPROVED <u>4/23/93</u>	EH SPECIALIST <u>E. Gloria Johnson</u>