

Granville - Vance District Health Department
Environmental Health
Well Construction Permit

1943


Owner/Applicant: John Thompson Date: 9-21-16
Address or Location of Property: Hallie Burnette Rd
(Before Burnette Rd on Right)
Subdivision & Lot #: Hallie Burnette 2+2 Septic Permit #:
Zoning Permit #: 19548 Environmental Health Specialist: Alan Curren

This well permit is to locate and site the area that a private groundwater well may be established on the property listed above by the Environmental Health Specialists of Granville County. If one does not locate the well in the approved area and complete the well as specified by the 15A NCAC .02C rules, then permits may be revoked. At completion of drilling of the well, grout must be witnessed by EHS and a well log turned into Environmental Health.

Minimum Setbacks: (these are the main setbacks, but not all required setbacks)

Setback from property lines - 10 ft Setback from septic tank and drain field, including repair area - 100 ft
Setback from structural foundations - 25 ft Setback from ponds, lakes or other bodies of water - 50 ft

Site Sketch:



Conditions: Well will serve lots
1 + 2, well will be located
on lot #1

Authorized Agent: _____
Date: _____

1 Well Grout: (Circle or write in)

Witnessed: Yes or No EHS Agent: _____
Date: _____ Annular Space Open: Yes or No
Over reamed: Yes or No Depth Grouted: _____
Method: _____ Pump _____ Poured _____ Pressure
Well Log received: Yes or No (EHS to Attach to Permit)
Driller Name: _____ Cert. # _____
Depth: _____ Casing Depth: _____ GPM: _____

As Built Drawing:



2 Well Final: (Place a check mark when finalized)

Seal Present and Intact: _____ Air Vent: _____
Hose Spigot: _____ Electrical Box: _____
Pump Installer Tag: _____ Well Installer Tag: _____
All holes sealed: _____ 12" above grade: _____
Comments: _____

3 Well Completion Permit: _____ EHS
Date Completed: _____

4 Water Samples Taken: Date: _____
EHS: _____ Results: _____
Retest: _____ Results: _____

Granville County Health Department
Environmental Health

Permit Number 1943

Improvement Permit

Construction Authorization

Well
SITE SKETCH

John Thompson
Applicant's Name

Hallie Burnette
Subdivision - Section - Lot

Adam Green
Authorized State Agent

9-21-16
Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to insure the proper grade is established.

* Well on lot
#1 will serve houses
on lots 1 + 2.

