

Revised

**Franklin County Health Department
Division of Environmental Health
107 Industrial Drive-Suite C
Louisburg, North Carolina 27549**

Phone: 919-496-8100

SEPTIC PERMIT

Fax: 919-496-8136

Permit Number: 4796 Type: I PIN: 2830-53-4909 Date: 1/27/2009

Applicant: OMAR WILLIAMS
100 RUSTLER RD
LOUISBURG, NC 27549

Owner: LAKE ROYALE POA
9022 LAKE ROYALE
LOUISBURG, NC 27549

Telephone: (252) 478-6083

Telephone:

Subdivision: LAKE ROYALE

Lot Number: 3314

Size: 1.000

Physical Address/ Location /Directions

Description: LifeTime _____ 5 Year X

TYPE FACIL SFO # EMPLOY 1 # BEDRMS 3 GPD 360 LTAR .359/a

TYPE WAT Com TYPE SYS I TYPE REP P+T BSMT N BST FX N/A

SIZE TANK 1000 SIZE CHB 1 SIZE NITR 3x300 MTD 36"

COMMENTS 3 BDR max w/ no basement

Septic Contractors are responsible for notifying the health department for final inspections, between 8:00-9:00 AM on the day of completion, Monday - Friday. Any request for final inspections received afterwards will be scheduled the same day, if possible, or the next workday. Have permit number and owner/applicant's name ready when making the call.

Actions of representatives of state or local agencies engaged in the evaluation and determination of measures required to effect the compliance with the provisions of this permit shall in no way be taken as a guarantee that wastewater disposal systems permitted and approved will function in a satisfactory manner for any given period of time, or that such employees assume any liability for damages, consequential or direct which are caused, or may be caused, by a malfunction of this wastewater treatment and disposal system.

Proper precautions must be taken to assure the proper functioning of the system after it has been covered. Do not run any heavy equipment over the system, as soft earth will allow damage to the tank and lines. Pipe all roof drains away from the septic system site to prevent flooding of the lines from surface water. Terrace the ground to prevent excessive drainage from higher areas adjacent to the system. Do not construct driveways over any part of the septic system unless proper provisions were made when the septic system was constructed. Only grass, not trees or shrubbery, should be cultivated over the lines. All plumbing fixtures should be carefully inspected periodically and any problems repaired immediately. All septic tanks should be pumped off by a permitted pump operator on a regular schedule, not to exceed every five years.

The improvement permit and construction authorization is a site approval, for the future installation of a wastewater treatment and disposal system. Changes in ownership of the site do not affect the validity of this permit. However, any alteration of the site or soil conditions, changes in the location of the proposed facility, changes to the wastewater flow and/or characteristics, or submittal of false information with the application or misrepresentation of the property lines may subject this permit to suspension or revocation.

FOR THIS TO BE A VALID CONSTRUCTION AUTHORIZATION, A LAYOUT SHEET MUST BE ATTACHED

IMPROVEMENT PERMIT

DATE

1/30/09

EHS

CONSTRUCTION AUTHORIZATION

DATE

1/30/09

EHS

[Signatures]

Franklin County Health Department

Name: WILLIAMS


Permit Number

4796

CONTRACTOR Dana Bortin TANK MANU DD31000 MANU DATE 5/6/10

WELL INSTALLED YES NO SYSTEM CODE E21203

SEPTIC SYSTEM LAYOUT (SKETCH SYSTEM LAYOUT HERE)



SEPTIC SYSTEM AS-BUILT (IF DIFFERENT FROM INITIAL LAYOUT) ON REVERSE

OPERATIONS PERMIT

DATE 6/29/10 EHS [Signature]

4796

COUNTY OF FRANKLIN

ENVIRONMENT HEALTH APPLICATION (496-8100)

Permit #: 25129

Permit Type: SEPTIC PERMIT

Date Issued: 01/26/2009

Project Address: ,

Location:

Size #: 1.000

Subdivision: LAKE ROYALE

Lot #: 3314

Applicant: WILLIAMS OMAR
100 RUSTLER RD
LOUISBURG NC 27549

Phone: 252-478-6083

Owner Name: LAKE ROYALE POA

Phone:

Owners Address: 9022 LAKE ROYALE

LOUISBURG, NC 27549

Tax record: 24150

Pin #: 2830-53-4909

Parcel #: LR1602 3314

Zoned: A R

Setbacks Front: 30

Rear: 25

Side: 10

Proposed Use: SFD

of bedrooms: 4

of people: 5

Township: CYPRESS

Public Water/Sewer: COUNTY

ST Road #:

Desc: 2830-53-4909

Fees Due: \$325.00

Date Paid: 01/26/2009

* Please complete all sections below*

☐ Yes ☒ No Does this site contain any previously identified jurisdictional wetlands?
☐ Yes ☒ No Is any wastewater, other than domestic, going to be generated?
☐ Yes ☒ No Is the site subject to approval by any other public agency?

*If the answer to any of the above is "yes", applicant must submit supporting documentation.

Please indicate desired system type(s). Systems can be ranked in order of preference.

☐ Conventional ☐ Accepted ☐ Modified Conventional ☐ Alternative
☐ Other ☒ No Preference

Call Environmental Health (919.496.8100) between 8:00 - 9:00 am Monday - Friday in order to schedule an appointment with an environmental health specialist for your lot evaluation. This application for an improvement permit/construction authorization and well permit does not constitute approval for zoning, septic or building permits. It will be necessary to meet all guidelines for zoning, septic and building permits prior to construction. The permit is valid for either 60 months or without expiration, depending upon documentation submitted. (complete site plan= 60 months---complete surveyed plat=without expiration.)

I hereby certify that I am the owner, or authorized by the owner to act as his/her legal representation. Furthermore, as legal representative (if applicable) I have advised the owner of my intention to apply for this wastewater treatment and disposal system and drinking water and well system permit.

I also certify that all of the statements made in this application and any attached documents are true, complete, and correct, to the best of my knowledge and belief, and are made in good faith. If information in this application for these improvements is falsified, changed or site is altered, then improvement permits and authorization to construct these improvements shall become invalid. Authorized county representatives are granted right of entry to make these evaluations or inspections, and to release information upon public request.

X Barbara Franks Barbara Franks
Print & Signature of Owner or Owner's Legal Representative

01/26/2009



HOUSE + GARAGE
— 75' —

3%

RUSTLER RD

