

PERMIT IS SUBJECT TO REVOCATION IF SITE PLANS OR INTENDED USE CHANGE

WARREN COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

544 WEST RIDGEWAY STREET

WARRENTON, NC 27589

PHONE (252) 257-1538

FAX (252) 257-4460

Permit No. 5252

Fee 150.00

Paid 8/1/05

Tax Parcel ID# J2A131

- (☒) Provisionally Suitable
() Pump system
() Repair of existing system

Name of original owner _____
Year _____

IMPROVEMENT PERMIT

Owner Paul W. Mickelsen Phone #: 252-586-7288
Address 109 Bright Leaf LANDING Littleton NC 27508
Subdivision Name GASTON Heights Lot # 29 Block # _____ Section # _____
Directions to lot (RPR#) Woodlands DR, Property on left!

Application Date 8/1/05

— Improvement permit with scale drawing on plat is valid without expiration

IMPROVEMENT PERMIT APPROVAL

Date 8/2/05 Andy Smith, RS ✓
Environmental Health Specialist

— Improvement permit with site plan is valid for 60 months

CONSTRUCTION AUTHORIZATION

Original Deed Date _____ Land Use Residence # of bedrooms 3 # of people 4
Water Supply Community Well Distance from well and/or water lines 100'/10'
Well installed at time of inspection (☒ Yes () No) Dist. from septic system 100'
Design daily flow of sewage 360 gals. Kitchen garbage grinder NO Other _____
Septic tank capacity 1000 gals. Nitrification field 1200 Sq. Ft.
Maximum trench depth 24 inches Type system Conv.
Type repair Innov.

CONSTRUCTION AUTHORIZATION APPROVAL

Date 8/2/05 Andy Smith, RS
Environmental Health Specialist

*CONSTRUCTION AUTHORIZATION IS VALID FOR 5 YEARS FROM DATE OF ISSUE

COMMENTS: (1) RUN TRENCHES 3' WIDE AND AT LEAST 9' ON CENTERS
(2) RUN LINES CONTOUR TO SLOPE (3) RUN LINES OF EQUAL LENGTH
(4) EFFLUENT FILTER REQUIRED (5) TANK MARKERS/RISERS NECESSARY
(6) IF TANK LOCATION IS SPECIFIED ON SITE PLAN SEPTIC PERMIT-
HOUSE, MH OR STRUCTURE TO BE PLUMBED ACCORDINGLY. (7) INSTALL INITIAL SYSTEM IN DESIGNATED AREA

Contact HD ONCE LOT
IS Cleared FOR EXACT
LAYOUT OF SYSTEM

THE SEPTIC TANK SYSTEM AND OTHER IMPROVEMENTS THAT ARE MADE SHALL BE INSTALLED AS SHOWN IN THE SITE SKETCH PLAN. NO CHANGES SHALL BE MADE WITHOUT APPROVAL FROM THE HEALTH DEPARTMENT.

ANY VARIATIONS FROM THE CONDITIONS AND REQUIREMENTS PREVIOUSLY DESCRIBED WILL VOID THE PERMIT. THIS IS AN OFFICIAL DOCUMENT. PLEASE RETAIN WITH

OTHER VALUABLE PAPERS.

*DO NOT LANDSCAPE LOT BEFORE HEALTH DEPARTMENT APPROVAL. DO NOT LOCATE DRIVEWAYS, PARKING AREAS, OR OTHER BUILDINGS OVER SEPTIC TANK SYSTEM. LANDSCAPE AREA OVER SEPTIC TANK SYSTEM TO PREVENT PONDING OF WATER. SEED WITH GRASS TO HELP PREVENT SOIL EROSION AND TO IMPROVE EVAPOTRANSPIRATION.

OPERATION PERMIT

OPERATION PERMIT APPROVAL

DATE _____
ENVIRONMENTAL HEALTH SPECIALIST

CONTRACTOR: _____

NOTE: THE SEPTIC TANK, AND NITRIFICATION FIELD MUST BE INSPECTED BY A REPRESENTATIVE OF THE HEALTH DEPARTMENT BEFORE THEY ARE COVERED.


THE SIGNING OF THIS CERTIFICATE SHALL INDICATE THAT THIS SYSTEM HAS BEEN INSTALLED IN COMPLIANCE WITH THE CURRENT LAW & RULES FOR SANITARY SEWAGE COLLECTION, TREATMENT AND DISPOSAL SET FORTH IN ARTICLE 11 OF GENERAL STATUTE 130A. SECTION. 1900 OF THE NORTH CAROLINA ADMINISTRATIVE CODE TITLE 10, HEALTH SERVICES. ENVIRONMENTAL HEALTH SUBCHAPTER 10A SANITATION AND SHALL IN NO WAY BE A GUARANTEE THAT THE SEPTIC TANK SYSTEM WILL FUNCTION SATISFACTORILY FOR ANY GIVEN PERIOD OF TIME.

WARREN COUNTY ENVIRONMENTAL HEALTH SECTION

SITE PLAN/SYSTEM LAYOUT

Applicant Paul W. Mickelsen Subdivision/Lot# GASTON Heights/Lot 29
 Authorized Agent Andy Smith, RS Date 8/2/05

System components represent approximate contours only. The contractor must flag the system prior to beginning installation to insure that proper grade is maintained.



Linear feet of conventional trench 400 Linear feet of 25% reduction trench _____ # of panels/bundles _____
 Maximum trench depth 24" SETBACKS: House foundation-5 ft; Basement-15ft; well- 100 ft
 Property line 10 ft; Stream/Lake-50ft; Gully-15ft; water pipe-10ft; Other _____
 Trenches on 9-ft centers, 3-ft wide, on contour, and installed in area shown.

PERMIT IS SUBJECT TO REVOCATION IF SITE PLANS OR INTENDED USE CHANGE

WARREN COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

544 WEST RIDGEWAY STREET

WARRENTON, NC 27589

PHONE (252) 257-1538

FAX (252) 257-4460

Permit No. 5251

Fee 150.00

Paid 8/1/05

Tax Parcel ID# 52A 132

- (☒) Provisionally Suitable
() Pump system
() Repair of existing system

Name of original owner _____
Year _____

IMPROVEMENT PERMIT

Owner Paul Mickelsen Phone #: 586-7288

Address 109 Bright Leaf LANDING Littleton

Subdivision Name GASTON Heights Lot # 30 Block # _____ Section # _____

Directions to lot (RPR#) Woodland Rd., Lot on left

Application Date 8/1/05

— Improvement permit with scale drawing on plat is valid without expiration

IMPROVEMENT PERMIT APPROVAL

Date 8/2/05 Andy Smith, RS ✓
Environmental Health Specialist

— Improvement permit with site plan is valid for 60 months

CONSTRUCTION AUTHORIZATION

Original Deed Date _____ Land Use Residence # of bedrooms 3 # of people 4

Water Supply Community Well Distance from well and/or water lines 100' / 10'

Well installed at time of inspection (☒) Yes () No

Dist. from septic system 100' (+)

Design daily flow of sewage 360 gals.

Kitchen garbage grinder NO Other _____

Septic tank capacity 1000 gals.

Nitrification field 1200 Sq. Ft.

Maximum trench depth 28" inches

Type system Conv.

Type repair Repair

CONSTRUCTION AUTHORIZATION APPROVAL

Date 8/2/05 Andy Smith, RS
Environmental Health Specialist

*CONSTRUCTION AUTHORIZATION IS VALID FOR 5 YEARS FROM DATE OF ISSUE

*Contact HD once
Lot is Cleared For
EXACT LAYOUT!

COMMENTS: (1) RUN TRENCHES 3' WIDE AND AT LEAST 9' ON CENTERS
(2) RUN LINES CONTOUR TO SLOPE 3) RUN LINES OF EQUAL LENGTH
(4) EFFLUENT FILTER REQUIRED 5) TANK MARKERS/RISERS NECESSARY
6) IF TANK LOCATION IS SPECIFIED ON SITE PLAN SEPTIC PERMIT-
HOUSE, MH OR STRUCTURE TO BE PLUMBED ACCORDINGLY. 7) INSTALL INITIAL SYSTEM IN DESIGNATED AREA

THE SEPTIC TANK SYSTEM AND OTHER IMPROVEMENTS THAT ARE MADE SHALL BE INSTALLED AS SHOWN IN THE SITE SKETCH PLAN. NO CHANGES SHALL BE MADE WITHOUT APPROVAL FROM THE HEALTH DEPARTMENT.

ANY VARIATIONS FROM THE CONDITIONS AND REQUIREMENTS PREVIOUSLY DESCRIBED WILL VOID THE PERMIT. THIS IS AN OFFICIAL DOCUMENT. PLEASE RETAIN WITH

OTHER VALUABLE PAPERS.

*DO NOT LANDSCAPE LOT BEFORE HEALTH DEPARTMENT APPROVAL. DO NOT LOCATE DRIVEWAYS, PARKING AREAS, OR OTHER BUILDINGS OVER SEPTIC TANK SYSTEM. LANDSCAPE AREA OVER SEPTIC TANK SYSTEM TO PREVENT PONDING OF WATER. SEED WITH GRASS TO HELP PREVENT SOIL EROSION AND TO IMPROVE EVAPOTRANSPIRATION.

OPERATION PERMIT

OPERATION PERMIT APPROVAL

DATE _____
ENVIRONMENTAL HEALTH SPECIALIST

CONTRACTOR: _____


NOTE: THE SEPTIC TANK, AND NITRIFICATION FIELD MUST BE INSPECTED BY A REPRESENTATIVE OF THE HEALTH DEPARTMENT BEFORE THEY ARE COVERED.

THE SIGNING OF THIS CERTIFICATE SHALL INDICATE THAT THIS SYSTEM HAS BEEN INSTALLED IN COMPLIANCE WITH THE CURRENT LAW & RULES FOR SANITARY SEWAGE COLLECTION, TREATMENT AND DISPOSAL SET FORTH IN ARTICLE 11 OF GENERAL STATUTE 130A. SECTION. 1900 OF THE NORTH CAROLINA ADMINISTRATIVE CODE TITLE 10, HEALTH SERVICES. ENVIRONMENTAL HEALTH SUBCHAPTER 10A SANITATION AND SHALL IN NO WAY BE A GUARANTEE THAT THE SEPTIC TANK SYSTEM WILL FUNCTION SATISFACTORILY FOR ANY GIVEN PERIOD OF TIME.

SITE PLAN/SYSTEM LAYOUT

Client Paul Mickelsen Subdivision/Lot# GASTON Heights/Lot 30
 Authorized State Agent Andy Smith, RS Date 8/2/05

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to insure that proper grade is maintained.



WOODLAND DR.

CONDITIONS OF THE PERMIT
 Linear feet of conventional trench 400' Linear feet of 25% reduction trench _____ # of panels/bundles _____
 Trench depth 28" SETBACKS: House foundation-5 ft; Basement-15ft; well- 100 ft
 Line 10 ft; Stream/Lake-50ft; Gully-15ft; water pipe-10ft; Other _____
 on 9-ft centers, 3-ft wide, on contour, and installed in area shown.

SITE PLAN

Borrower or Owner Thompson and Randall
100 Highland Road

Borrower or Owner R. Thompson
Property Address Lot 30 Woodland Road

City Littleton

County Warden

544 NC

Zip Code 27850

Lender or Client **BB & T**

