

GRANVILLE VANCE**public health****Well Construction Permit**

Vance County Health Dept
Environmental Health
115 Charles Rollins Road
Henderson NC, 27536
Phone: (252) 492-5263 Fax: (252) 492-2361

For Office Use Only

*CDP File Number 410790PIN Number: 0600B01004Tax Lot #: 52

Tax Block #: _____

Evaluated For: DRINKING WATER WELL \ WELLPERMIT VALID UNTIL: 04/05/2029

Property Owner: Joi Sandlin & Earl Fox
Address: 86 Sam Brummitt Rd
City: Henderson
State/Zip: NC / 27537
Phone #: C: (401) 456-3720

Applicant: Joi Sandlin & Earl Fox
Address: 86 Sam Brummitt Rd
City: Henderson
State/Zip: NC / 27537
Phone #: C: (401) 456-3720

Property Location & Site Information

Address/Road #:

155 Sam Brummitt RdHenderson NC, 27537Subdivision: Kerr Lake Estates

Phase: _____

Lot: 52*Proposed use of Well: DRINKING WATER WELL

If Other: _____

Applicant Email: dennis.1.sandlin@gmail.comOwner Email: dennis.1.sandlin@gmail.com**Directions:** See attached**Well Contractor Information**

Drilling Contractor: _____

Driller Registration: _____

Permit Conditions***Permit Conditions**

well shall be 25ft from the home including overhangs, 50ft from any septic, approx 20ft from existing well, and 10ft from property lines.

Well location, construction and protection must meet all state and local regulations and must be inspected and approved by an authorized representative of the Local Health Department. The permit may be revoked at any time for failure to comply with existing regulations. The siting of approved well construction area(s) by the Health Department is to provide protection from the known possible sources of contamination. The approved well area(s) may not be changed without permission from an authorized representative of the Local Health Department. Issuance of this well permit does not guarantee water quality or adequate water production from the well once it is installed or repaired.

*Issued By: Diamond, Chris

Authorized State Agent: _____

Owner/Applicant: _____

*Date of Issue: 04/05/2024☐ Hand Drawing☐ Import Drawing****Site Plan/Drawing attached.****

Granville-Vance Dist. Health Department
Environmental Health

Plot _____

Permit Number 410790

____ Improvement Permit

8 Construction Authorization

**SITE SKETCH
ON-SITE / WELL**

Sci Sandlin
Applicants Name

155 Sam Brumitt Rd
Address

Kerrlake Estates .. Lot 52
Subdivision - Section - Lot

Ch R...
Authorized State Agent

4-5-24
Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that proper grade is maintained.

