

WAKE COUNTY, NORTH CAROLINA
 I, James E. Chapman
July 14, 2004

This certification does not represent approval or a permit for any
 site work or wastewater system modification/repairs. Additionally,
 any change in use, site alteration or misrepresentation of existing
 conditions may result in suspension or revocation of certification.
 Date 7/14/04 Signature James E. Chapman
 Notarized in the County of Wake

1. 100 YEAR FLOOD LINE TAKEN
 WAKE COUNTY G.I.S. MAPS. SEE
 PANEL# 37183CO135 E, DATED
 4-03, 1992

TNEA CREEK DEVELOPMENT CO. INC.
 BOOK 8507, PAGE 2040)
 1 GLEN SUBDIVISION (PHASE 2)
 F MAPS 2001, PAGE 2338
 11-04-51-8075

- CA for D59072
- Install a 1200 gallon septic tank and d-box.
 - Install three lines (140"x3") of accepted status product
 - Maintain all setbacks
 - Max Trench Depth 24"
 - Ensure d-box and lines no closer than 10' to property



NO NG GRID

