Environmental Services - Water Quality
Onsite Wastewater Scan Data Entry Form

PERMIT #: C 0 1 9 1 8 7 PIN #: 0 6 9 9 5 6 7 1 9 2

OP DATE: 0 2 / 1 5 / 1 9 9 5

SYSTEM USE:
- [x] House
- [ ] Mobile Home
- [ ] Business
- [ ] Other

SEWAGE TYPE:
- [x] Domestic
- [ ] Industrial

PUMP/SIPHON?:
- [ ] Yes
- [x] No

PRESSURE MANIFOLD:
- [ ] Yes
- [x] No

SYSTEM TYPE:
- [ ] I
- [x] II
- [ ] III
- [ ] IV
- [ ] V
- [ ] VI
- [ ] Other

SUB TYPE:
- [x] A
- [ ] B
- [ ] C
- [ ] D
- [ ] E
- [ ] F
- [ ] G

NBR BEDROOMS:
- [ ] 1
- [ ] 2
- [x] 3
- [ ] 4
- [ ] 5
- [ ] 6
- [ ] Other

MAINT. SCHEDULE:
- [ ] Yes
- [x] No

CERT. OPERATOR
- [ ] Yes
- [x] No

GT	ST	PT	SIZE
☐	☐		750
☐	☐	☐	900
☐	☒	☐	1,000
☐	☐	☐	1,200
☐	☐	☐	1,500
☐	☐	☐	1,800
☐	☐	☐	2,100
☐	☐	☐	2,500
☐	☐	☐	3,000
☐	☐	☐	4,000
☐	☐	☐	5,000
☐	☐	☐	8,000
	☐	☐	10,000
☐	☐	☐	Other
☒		☒	None/NA GT or PT

DRAINFIELD SIZE(SQ. FT.)

0 1 0 2 6

DRAIN TYPE:
- [x] Stone
- [ ] EZ Flow
- [ ] Infiltrator
- [ ] Biodiffuser
- [ ] Cultec
- [ ] Drip
- [ ] Hancor
- [ ] Large Dia. Pipe
- [ ] Multi-Pipe
- [ ] Other

MAX DEPTH (IN.):
- [ ] 12 in. or less
- [ ] 18 in. or less
- [x] 24 in. or less
- [ ] 26 in. or less
- [ ] 28 in. or less
- [ ] 30 in. or less
- [ ] 32 in. or less
- [ ] 36 in. or less
- [ ] Other

STONE DEPTH (IN.):
- [ ] 8 in. or less
- [x] 12 in. or less
- [ ] 18 in. or less
- [ ] 24 in. or less
- [ ] Other

TRENCHES:
- [x] Individual
- [ ] Bed

TRENCH WIDTH (IN.):
- [ ] 12 in. or less
- [ ] 18 in.
- [ ] 24 in.
- [x] 36 in.
- [ ] 6 ft. or less
- [ ] 9 ft. or less
- [ ] Other

B.W 9/23/14

WAKE COUNTY HEALTH DEPARTMENT WELL AND SEWAGE SITE, LOCATION PERMIT

ALL PERMITS VOID 60 MONTHS FROM DATE OF ISSUANCE

Pin # 0699.02 56 7142 Project # 0941797

Tax Map No. [illegible] Parcel No. _____

Zoning 40W Township PANTHER BRANCH

Owner/Contractor: LYNN PARRISH BLDRS.

Location/Address: 1000 SOUTH KNOLL CT.

KB 12-5-95

Improvement Permit

Well Permit No. C 19187

Operation Permit [ ]

Date: 1/28/94

S.R. # 1010

Subdivision Name: SOUTH MOUNTAIN Lot No. 12 Section or Block No. ~~1010~~

Tax Map No. _____ Parcel No. _____

Preliminary Layout



Final Layout



Sewage System Specifications

Repair [ ] Original Permit No. _____

Garbage Disposal Unit Yes [ ] No [✓]

House [✓] Mobile Home [ ] Business [ ]

No. of Bedrooms 3 Lot Area .96 Ac

Size of Tank 5T - 1000 gal.

Comments: *STAY OUT OF RELIC DRAINAGEWAY - INSTALL ON CONTOUR

Nitrification Line 2 (3' x 171') = 1026 sq. ft.

Depth of Stone: 12" [✓] Max Depth of Trenches: 24 in.

Riser and Baffle Required [✓] Pump Required [ ]

☛ Permit void if not in compliance with zoning regulations

☛ Permits may be voided if site is altered or intended use changed

Layout by: Steve E. Smith EHS I

Date: 2-15-95 Installed By: Brantley Approved By: Andrea C. Reece, R.S.

Well System

Individual [ ] Semi-Public [ ] Public [✓]

New [ ] Replacement [ ] Repair [ ]

Fee Paid: Yes [ ] No [ ]

Construction Compliance	Yes	No
Site Approved	[ ]	[ ]
Well Head Approved	[ ]	[ ]
Grouting Approved	[ ]	[ ]

_____ _____

Date Inspected *Sanitarian*

Bacteriological Results

Initial Sample: _____ Date: _____

* Re-Sample #1 _____ Date: _____

* Re-Sample #2 _____ Date: _____

* Re-chlorination as required [ ] Yes [ ] No

* *Fees for all resamples*

All checks payable to: **Wake County Health Department**

Final Inspection	Yes	No
Required Slab	[ ]	[ ]
Chlorinated	[ ]	[ ]
Required Certificate	[ ]	[ ]
Variance (Explain)	[ ]	[ ]
WCHD I.D. Affixed	[ ]	[ ]
Sample Collected	[ ]	[ ]

Comments: _____

Well Installed By: _____

_____ _____

Date System Finalized *Sanitarian*

This report is based in part on information provided by the homeowner or his/her representative in the application submitted for this permit. The sanitarian is not responsible for false or misleading information contained in the application. The sanitarian is also not responsible for concealed conditions on the property or for statements in this report that may have resulted from false or misleading statements provided to him in the application. Neither Wake County nor the sanitarian warrants that the septic tank system will continue to function satisfactorily in the future or that the water supply will remain potable.

COPY TO HEALTH DEPARTMENT

3002.017 — 5/14/93