



Specialty Testing

Well Water Test Report
Specialty LLC, NC DPH/EPA Lab ID 37909
336.510.7333
SpecialtyTesting.com

Report ID: 12906112601680
Report Date: 6/12/2026
Client or Representative: Sparrow Point
Location Address: 5901 Ten-Ten Rd. Apex, NC 27539
Sample Collected by: Collected and submitted by client as identified as "Client or Representative" above
Sample Analysis by: JET, AR, GAP
Sample Results:

FAILURES REPORTED; not all performed tests PASSED EPA and local requirements.	
FAILURES REPORTED; not a passing test result.	
Total Coliform Presence/Absence: Test was POSITIVE for Total Coliform (PRESENT / > 1 CFU/100 mL) - FAIL	
E. coli Presence/Absence: Test was NEGATIVE for E. coli (Not present / <1 CFU/100 mL) - PASS	
End of test results.	

<https://www.arhs-nc.org/assets/media/pdf/DisinfectWell.pdf>

Testing performed by Specialty LLC, NC EPA Laboratory ID Number 37909, Microbiology and Inorganic Chemistry Certifications.
This is a true and certified copy of an original report kept by Specialty Testing.
All legal agreements and terms of this report and its use are available at SpecialtyTesting.com

Authorized Laboratory Personnel

6/12/2026

Date

Thank you for using Specialty Testing
For further testing, or to refer someone else to us, please visit www.SpecialtyTesting.com.