

WAKE COUNTY HEALTH DEPARTMENT SEPTIC TANK LAYOUT AND PERMIT

TAX MAP NO. 698

PARCEL NO. 184(5)

CONTRACTOR High Meadows Const Co.

PERMIT NO. B 31118
Smith Cr 0760 67 0619

OWNER 13

DATE 3/5/85

LOCATION 4113 Leo Arches Ct.

S. R. NO. 1152

SUBDIVISION NAME Leo Arches

LOT NO. 4

SECTION OR BLOCK NO. 1

REPAIR ☐ ORIGINAL PERMIT NO. _____

GARBAGE DISPOSAL UNIT YES ☐ NO ☒

HOUSE ☒ MOBILE HOME ☐ BUSINESS ☐

NO. BEDROOMS 3 LOT AREA 1.723 AC

SIZE OF TANK 1000 gal.

NITRIFICATION LINE 2(3' @ 183') 1100 sq. ft.

DEPTH OF STONE IN LINES: 12" ☒

RISER AND BAFFLE REQUIRED ☒ PUMP REQUIRED ☐

WATER SUPPLY: INDIVIDUAL ☒ PUBLIC ☐ OTHER ☐

* PERMIT VOID 36 MONTHS FROM DATE OF ISSUANCE.

* PERMIT VOID IF NOT IN COMPLIANCE WITH ZONING REGULATIONS

* PERMIT MAY BE VOIDED IF SITE ALTERATIONS MADE

LAYOUT BY Hene Banton

DATE 7/15/85

INSTALLED BY Wendy Wilson

APPROVED BY Hene Banton

590-GP09

