

HAL OWEN & ASSOCIATES, INC.

SOIL & ENVIRONMENTAL SCIENTISTS

P.O. Box 400, Lillington, NC 27546-0400

Phone (910) 893-8743 / Fax (910) 893-3594

www.halowensoil.com

02 April 2026

Tom Banks

Reference: Preliminary Soil Investigation
Lake Wheeler Road
Wake Co., NC; PIN 0689452507

Dear Mr. Banks,

A site investigation has been conducted for the above referenced property, located on the eastern side of Lake Wheeler Road in Wake County, North Carolina. The purpose of this investigation was to determine the site's ability to support subsurface wastewater dispersal systems. All sewage disposal ratings and determinations were made in accordance with the Rules for "Wastewater Treatment and Dispersal Systems", 15A NCAC 18E. This report represents my professional opinion as a Licensed Soil Scientist.

The soils were evaluated under moist soil conditions through the advancing of auger borings. This property was observed to be underlain by soils that are rated as unsuitable for subsurface wastewater dispersal systems (see attached map). These soils are so rated due to inadequate soil depth to excessive soil wetness conditions. Current regulations will not permit subsurface wastewater systems to be installed in areas rated as unsuitable.

Potential wetlands were observed during the investigation and are approximately shown on the attached map.


I appreciate the opportunity to provide this service and regret that more favorable findings could not be reported. If you have any questions or need additional information, please contact me at your convenience.



Sincerely,

A handwritten signature in black ink that reads 'Britt Wilson'. The signature is fluid and cursive, with the first name 'Britt' and last name 'Wilson' clearly distinguishable.

Britt Wilson
Licensed Soil Scientist



Hal Owen & Associates Inc.
PO Box 400, Lillington, NC 27546
www.halowensoil.com
919-893-8743

0 60 120 ft



For reference only. Not a survey.

Lake Wheeler Road
Wake Co., NC
PIN 0689452507

02 April 2026

Preliminary
Soil Map for Septic Suitability