

Permit Summary

|               |                                                                                     |
|---------------|-------------------------------------------------------------------------------------|
| Permit Type   | MECHANICAL TRADE PERMIT                                                             |
| Permit #      | 2026-00056160                                                                       |
| Application # |                                                                                     |
| Status        | Permit Completed on 03/25/2026 (Fees will appear once the permit has been approved) |
| Issued To     | Contractor                                                                          |

Payment Summary

|                  |            |
|------------------|------------|
| Total Charges    | \$80.00    |
| Amount Collected | \$80.00    |
| Total Due        | \$0.00     |
| Paid On          | 03/10/2026 |

Location

|                      |                                                                                                                                    |
|----------------------|------------------------------------------------------------------------------------------------------------------------------------|
| Primary Owner        | HOREAU, RYAN MOREAU, LAUREN                                                                                                        |
| Address              | 1101 PREWITT RANCH DR<br>HOLLY SPRINGS NC, 27540                                                                                   |
| Parcel               | 0657442008                                                                                                                         |
| Description          | BRJAR GATE LOT 39 - HVAC CHANGEOUT                                                                                                 |
| Location Description | 1101 PREWITT RANCH DR                                                                                                              |
| Lot Number           | 39                                                                                                                                 |
| Subdivision          | BRJAR GATE                                                                                                                         |
| Comments             | Replacement of (1) 3.5 ton split heat pump, work being performed on left side of home and in the attic, system to serve whole home |

Permit Details

|                        |                                                                                                                                    |
|------------------------|------------------------------------------------------------------------------------------------------------------------------------|
| Description            | BRJAR GATE LOT 39 - HVAC CHANGEOUT                                                                                                 |
| Current Property Value |                                                                                                                                    |
| Est. Improvement Value | \$14,800.00                                                                                                                        |
| Improvement Sq. Ft.    |                                                                                                                                    |
| Permitted              |                                                                                                                                    |
| Approved               |                                                                                                                                    |
| Notes                  | Replacement of (1) 3.5 ton split heat pump, work being performed on left side of home and in the attic, system to serve whole home |
| Comments               |                                                                                                                                    |
| Other Information      |                                                                                                                                    |
| Other Party            |                                                                                                                                    |
| Address                |                                                                                                                                    |

Inspections

|                                                                                            |                    |                            |           |           |                                                                                             |
|--------------------------------------------------------------------------------------------|--------------------|----------------------------|-----------|-----------|---------------------------------------------------------------------------------------------|
| NOTE: If the inspection you require is not listed, please call (919) 552-1403              |                    |                            |           |           |                                                                                             |
| ** Attention: Do NOT schedule inspections until the Permit has been PAID FOR and ISSUED ** |                    |                            |           |           |                                                                                             |
| Date                                                                                       | Inspection Type    | Request Inspection Comment | Status    | Pass/Fail | Inspector Comment                                                                           |
| 03/19/2026                                                                                 | E-ELECTRICAL FINAL | morning please             | Completed | Fail      | 3/19/26 Electrical Final 1. AC labeled for max breaker of 40 amps, 45 amp breaker installed |
| 03/25/2026                                                                                 | E-ELECTRICAL FINAL | Add Comment                | Completed | Pass      | 3/19/26 Electrical Final 1. AC labeled for max breaker of 40 amps, 45 amp breaker installed |
| 03/19/2026                                                                                 | M-MECHANICAL FINAL | morning please             | Completed | Pass      |                                                                                             |

REQUEST