

Summary ☺

Application Number: 2016-00001749-13160

Application Type: Irrigation - Reclaimed Water System

Application Status: Closed

Property Owner's Full Name: VELEZ, JOSE S II

Category of Work: Other

Description of Work: 12 Oaks, Reclaim Irrigation
12 Oaks, Reclaim Irrigation

Application Date: 09/21/2016

Issued Date: 10/05/2016

Date Finaled: 09/21/2016

Reclaimed Rough-in Code Inspection	Failed	10/7/2016	10/7/2016	10/07/2016
Clyde Stephenson ((919) 524-2617) Inspector: 89 Reclaim Irrigation Rough In Code Failed Comments: 1- Cannot verify that irrigation piping purple in color and buried minimum of 12" 2- Expose a few locations to verify item 1				
Reclaimed Rough-in Code Inspection	Failed	10/19/2016	10/19/2016	10/19/2016
Clyde Stephenson ((919) 524-2617) 89 Reclaim Irrigation Rough In Code Reinspection fee \$75 Inspector: Failed Comments: 1- Cannot verify that irrigation piping purple in color and buried minimum of 12" 2- Expose a few locations to verify item 1 3- No permit card on job site				
Reclaimed Final Engineering Inspection	Failed	10/26/2016	10/26/2016	10/26/2016
Mike Ritter ((919) 291-5780) Inspector: 91 Reclaim Irrigation Final Eng Reinspection fee \$75.00 Comments: PER LAST INSPECTION: 1- Reclaim was exposed in two locations and pipe is less than the required minimum 12" at approx. 5-1/2".				
Reclaimed Rough-in Code Inspection	Passed	10/31/2016	10/31/2016	10/31/2016
Clyde Stephenson ((919) 524-2617) Inspector: 89 Reclaim Irrigation Rough In Code Approved Comments: 1- Ok to Cover				
Reclaimed Final Code Inspection	Failed	11/3/2016	11/3/2016	11/03/2016
Clyde Stephenson ((919) 524-2617) Inspector: 90 Reclaim Irrigation Final Code Failed Comments: 1- Final not done no meter set				
Reclaimed Final Engineering Inspection	Failed	11/3/2016	11/3/2016	11/03/2016
NA 91 Reclaim Irrigation Final Eng Reinspection fee \$75.00 Inspector: PER LAST INSPECTION: Comments: 1- Reclaim was exposed in two locations and pipe is less than the required minimum 12" at approx. 5-1/2". No one onsite and no contact made with specific time for the inspection				
Reclaimed Final Code Inspection	Passed	11/8/2016	11/8/2016	11/08/2016
Inspector: Clyde Stephenson ((919) 524-2617) Comments: 90 Reclaim Irrigation Final Code Approved				