

Jon & Ashley,

The average indoor radon level during the testing period was 1.0 pCi/L (below the 4.0 pCi/L EPA Action Level). No further action is recommended at this time.

Thanks for using our service,

Glenn Steers
Wake Radon

glenn@wakeradon.com
<https://wakeradon.com>