

WAKE COUNTY DEPARTMENT OF ENVIRONMENTAL SERVICES WASTEWATER PERMIT

NO PERMIT(S) FOR CONSTRUCTION, LOCATION OR RELOCATION ACTIVITY SHALL BE ISSUED UNTIL AN AUTHORIZATION FOR WASTEWATER SYSTEM CONSTRUCTION AUTHORIZATION HAS BEEN ISSUED

PERMIT VOID IF NOT IN COMPLIANCE WITH ZONING REGULATIONS AND/OR IF SITE IS ALTERED OR INTENDED USE CHANGED

OPERATIONS PERMIT

PERMIT # WREP-175152-2026

APPLICATION DATE: 07/06/2026

BLDG. PERMIT#:

PIN: 0788430695

RECORDED: Yes

TOWNSHIP: 08 - Leesville

JURISDICTION: Raleigh

ZONING: R-2

APPLICANT: Terry Hardin
8824 Woodyhill Rd

BUSINESS PHONE: (919) 374-0699

HOME PHONE: (919) 845-1860

MOBILE PHONE: (919) 374-0699

HD USE: 101A CONVENTIONAL ONE-FAMILY HOUSE

EXISTING USE: 101A CONVENTIONAL ONE-FAMILY HOUSE

SITE ADDRESS: 8824 WOODYHILL RD

SUBDIVISION: SPRINGDALE ESTS

LOT: 226

ACRES: 0.57

DIRECTIONS: GPS

Systems defined as either type III-b, III-g with a pump, IV, V or VI, in accordance with the North Carolina administrative code 15A NCAC 18a .1961, table V as adopted by reference in the "Regulations Governing Wastewater Treatment Dispersal Systems in Wake County", requires Wake County Environmental Services to conduct periodic inspections of the system type pursuant to 15A NCAC 18a. 1961 (j). Fees for these inspections will be charged as per the approved Fee Schedule. In addition, all systems are to be operated and maintained as specified in 15A NCAC 18A .1961. This permit is based in part on information provided by the homeowner and/or his/her representative in the application submitted for this permit. The Environmental Health Specialist is not responsible for false or misleading information contained in the application. The environmental health specialist is also not responsible for concealed conditions on the property or for statements in this report that may have resulted from false or misleading statements provided to him/her in the application. Neither Wake County nor the Environmental Health Specialist warrants that the septic tank system will continue to function satisfactorily in the future or that the water supply will remain potable.

OPERATION PERMIT VALID FOR: No Expiration

INSTALLED BY: TRUELOVE, DAVID H - 1243 - IV

PROPRIETARY SYSTEM: TANK - Septic/Pump Tank

PRETREATMENT SYSTEM:

Replacement

SYSTEM TYPE INSTALLED: II A

OPERATION PERMIT: STATUS: Issued

ISSUED BY: Joel Bendel

ISSUED DATE: 07/27/2026

SEPTIC TANK: Infiltrator - TW Series - 1500
gallons

DATE OF MANUFACTURE:

FILTER: Polylok - PL-68

GREASE TRAP:

DATE OF MANUFACTURE:

FILTER:

DOSING PUMP TANK:

DATE OF MANUFACTURE:

FILTER:

CC1: ETM1:

CC2:

ETM2:

RECIRCULATION TANK:

DATE OF MANUFACTURE:

CC1: ETM1:

CC2:

ETM2:

SEPTIC TANK ELEVATION: 5.50

GREASE TRAP ELEVATION:

DOSING PUMP TANK ELEVATION:

RECIRCULATION TANK ELEVATION:

DISTRIBUTION DEVICE ELEVATION: 5

INSTALLED TRENCH DEPTH	INSTALLED AGGREGATE DEPTH	INSTALLED TRENCH LENGTH	INSTALLED TRENCH BOTTOM ELEVATION

ACTUAL PRESSURE HEAD:

ACTUAL FLOW RATE:

ACTUAL DOSE VOLUME: 0

SPECIFIC OPERATION REQUIREMENTS:

NEW 1500 GALLON ST INSTALLED FOR A 4 BEDROOM DWELLING WITH A MAXIMUM OCCUPANCY OF 8 AND A DAILY FLOW OF 480 GPD.

ISSUED BY:



DATE: 07/27/2026