


- *Keep tanks and drain lines 10' from property lines.
- *Not a survey.
- *Not a guarantee of a septic permit.
- *Keep supply lines >5' from property lines.
- *Some lines are flagged longer in the field than lengths indicate.
- *No grading septic area.

System: Gravity to Serial Lines: 1-4a, (445')
Accepted Status System
0.3 Soil LTAR

Repair: Gravity to Serial Lines: 4b-9, (400')
Accepted Status System
0.3 Soil LTAR

System: —————
Repair: - - - - -
Soil Line: ————

25' TREE & VEGETATION BUFFER



0 30 60
SCALE:
1" = 60 ft.



Central Carolina Soil Consulting, PLLC
1900 South Main Street, Suite 110
Wake Forest, North Carolina 27587
Phone (919)569-6704 Fax (919)569-6703

Septic Site Plan
Lot 89, Wexford Subdivision Ph 2
4-Bedroom
Wake County, North Carolina

Job# : 4401
Drawn By : LW
Date : 7/11/2022
Revision: 12/7/2022