



Specialty Testing

Well Water Test Report
Specialty LLC, NC DPH/EPA Lab ID 37909
336.510.7333
SpecialtyTesting.com

Report ID: 12905162400980
Report Date: 5/17/2024
Client or Representative: New Leaf Home Inspections
Location Address: 1324 State Hwy 96 Zebulon, NC 27597
Sample Collected by: Collected and submitted by home inspector as identified as "Client" above
Sample Analysis by: JET, GAP
Sample Results:

No failures reported; all requested and performed tests PASSED EPA and local requirements.	
All performed inorganic chem or microbiological tests were NEGATIVE or below maximum contaminant (reporting) levels.	
Coliform Presence/Absence: Test was NEGATIVE for Coliforms (Not present / <1 CFU/100 mL) - PASS	
E. coli Presence/Absence: Test was NEGATIVE for E. coli (Not present / <1 CFU/100 mL) - PASS	
Selected analyte reported levels:	
	Nitrate levels reported below 10 mg/L (10ppm) - PASS
	Nitrite levels reported below 1 mg/L (1ppm) - PASS
	Lead levels reported below 0.015 mg/L (15ppb) - PASS

Testing performed by Specialty LLC, NC EPA Laboratory ID Number 37909, Microbiology and Inorganic Chemistry Certifications.
This is a true and certified copy of an original report kept by Specialty Testing.
All legal agreements and terms of this report and its use are available at SpecialtyTesting.com

Authorized Laboratory Personnel

5/17/2024

Date

Thank you for using Specialty Testing
For further testing, or to refer someone else to us, please visit www.SpecialtyTesting.com.