

Environmental Services - Water Quality
Onsite Wastewater Scan Data Entry Form

PERMIT #: D011131

PIN #: 6799470897

OP DATE: 12/14/1998

SYSTEM USE:

- ☒ House
☐ Mobile Home
☐ Business
☐ Other

SEWAGE TYPE:

- ☒ Domestic
☐ Industrial

PUMP/SIPHON?:

- ☐ Yes
☒ No

PRESSURE MANIFOLD:

- ☐ Yes
☒ No

SYSTEM TYPE:

- ☐ I
☒ II
☐ III
☐ IV
☐ V
☐ VI
☐ Other

SUB TYPE:

- ☒ A
☐ B
☐ C
☐ D
☐ E
☐ F
☐ G

NBR BEDROOMS:

- ☐ 1
☐ 2
☐ 3
☒ 4
☐ 5
☐ 6
☐ Other

MAINT. SCHEDULE:

- ☐ Yes
☒ No

CERT. OPERATOR

- ☐ Yes
☒ No

GT	ST	PT	SIZE
☐	☐		750
☐	☐	☐	900
☐	☐	☐	1,000
☐	☒	☐	1,200
☐	☐	☐	1,500
☐	☐	☐	1,800
☐	☐	☐	2,100
☐	☐	☐	2,500
☐	☐	☐	3,000
☐	☐	☐	4,000
☐	☐	☐	5,000
☐	☐	☐	8,000
☐	☐	☐	10,000
☐	☐	☐	Other
☒		☒	None/NA GT or PT

DRAINFIELD SIZE(SQ. FT.)

01371

DRAIN TYPE:

- ☒ Stone
☐ EZ Flow
☐ Infiltrator
☐ Biodiffuser
☐ Cultec
☐ Drip
☐ Hancor
☐ Large Dia. Pipe
☐ Multi-Pipe
☐ Other

MAX DEPTH (IN.):

- ☐ 12 in. or less
☐ 18 in. or less
☒ 24 in. or less
☐ 26 in. or less
☐ 28 in. or less
☐ 30 in. or less
☐ 32 in. or less
☐ 36 in. or less
☐ Other

STONE DEPTH (IN.):

- ☐ 8 in. or less
☒ 12 in. or less
☐ 18 in. or less
☐ 24 in. or less
☐ Other

TRENCHES:

- ☒ Individual
☐ Bed

TRENCH WIDTH (IN.):

- ☐ 12 in. or less
☐ 18 in.
☐ 24 in.
☒ 36 in.
☐ 6 ft. or less
☐ 9 ft. or less
☐ Other

DN

WAKE COUNTY DEPARTMENT OF ENVIRONMENTAL SERVICES WELL AND SEWAGE SITE LOCATION PERMIT

NO PERMIT(S) FOR CONSTRUCTION, LOCATION OR RELOCATION ACTIVITY SHALL BE ISSUED

UNTIL AN AUTHORIZATION FOR WASTEWATER SYSTEM CONSTRUCTION HAS BEEN ISSUED

PERMIT VOID IF NOT IN COMPLIANCE WITH ZONING REGULATIONS AND/ OR IF SITE IS ALTERED OR INTENDED USE CHANGED

PERMIT#: D011131 STATUS: A APP DATE: 07/06/1998 BLDG PERMIT#: 0990059

APPLICANT: SOVEREIGN HOMES INC DAY PHONE: (919) 380 - 8055

ADDRESS: 116 AGASSI CT FAX#: (000) 000 - 0000

CITY: CARY STATE: NC ZIP: 27511

OWNER: SOVEREIGN HOMES INC DAY PHONE: (919) 380 - 8055

ADDRESS: SAME FAX#: (000) 000 - 0000

CITY: CARY STATE: NC ZIP: 27511

HD USE CD: 101 ONE-FAMILY HOUSE ORIG PERMIT#: REC?: Y

EXIST USE: TAX MAP#: 0240

BEDROOMS: 4 BSMT: N #EMPLOYEES: 0 WATER: C WASTEWATER: I GARB DISPOSAL: N

TOWNSHIP: 02 BARTON'S CREEK JURIS: WC ZON: 40W PIN: 0799.01 47 0897 000

SUBD#: S 000 000 00 SUBD NAME: CHANDLER POINT LOT-SEC: 45 ACRE: 0.95

IMPRV PRMT: ISSUED?: Y DATE: 08/01/1998 BY: TDC TYPE SYSTEM: II PUMP:

CNSTR AUTH: ISSUED?: Y DATE: 08/01/1998 BY: TDC DATE EXPIRED: 08/01/2003

RECEIPT#: 0030546 FEE: 145.00 OP DATE: BY:

WATR SAMPL: REQ?: N APPROVED?: DATE: PROPRIETARY SYS:

ST#: 10212 MI: DIR: NAME: OLD WARDEN DIR: TYP: RD

DIRECTIONS: 50 N TO R ON OLD WARDEN RD LOTS ARE NUMBERED

IMPROVEMENT PERMIT

SIZE OF TANK 1200 ST PT GALS. TOTAL SQ. FT. 1371 DEPTH OF STONE 12 IN. MAX. DEPTH LINE 24 IN. KB

WASTEWATER: DOMESTIC ☒ INDUSTRIAL ☐

I.P. ISSUED BY

Terry D. Chappell R.S.

AUTHORIZATION FOR WASTEWATER SYSTEM CONSTRUCTION

VOID SIXTY (60) MONTHS FROM DATE OF ISSUANCE

AUTHORIZATION CONDITIONS

Contractor To Follow Contours, See Attached Site Plan For Wastewater System Design And Well Location. The wastewater system shall not be covered or placed into use until inspected by the Wake County Department of Environmental Services and an Operation Permit issued.

OTHER CONDITIONS: keep system shallow, 24inch max. depth, keep system 10 feet from property lines, Place 2nd riser on septic tank for access to septic tank filter, community water

SIZE OF TANK 1200 ST PT GALS. TOTAL SQ. FT. 1371 DEPTH OF STONE 12 IN. MAX. DEPTH LINE 24 IN.

ST FILTER REQUIRED ☒ NUMBER OF TRENCHES 2 LENGTH OF TRENCHES 228 FT. WIDTH OF TRENCHES 3 FT.

C.A. ISSUED BY Terry D. Chappell R.S. INSTALLED BY Shane Brantley CTR. I.D. # _____

SEPTIC TANK FILTER USED _____

INNOV. APPL. #: IWWS- _____ DATE 12/14/98 INSTALLATION APPROVED BY

Cynthia J. Maurice R.S.

WELL SYSTEM = PRIVATE ☐ SEMI-PUBLIC ☐ //// NEW ☐ REPLACEMENT ☐ EXISTING ☐

WELL LOG INFORMATION = DEPTH _____ CASING DEPTH _____ YIELD _____ STATIC LEVEL _____

WELL CONTRACTOR _____ REG.# _____ PUMP CONTRACTOR _____ REG.# _____

CONSTRUCTION COMPLIANCE = GROUT APPROVED ☐ DATE _____ EHS _____

WCHD ID # _____ WELLHEAD APPROVED ☐ DATE _____ EHS _____


NEGATIVE BACTERIOLOGICAL RESULTS ☐ DATE _____ EHS _____

SYSTEM FINALIZED ☐ DATE _____ EHS _____

COMMENTS: community water

This permit is based in part on information provided by the homeowner or his/her representative in the application submitted for this permit. The Environmental Health Specialist is not responsible for false or misleading information contained in the application. The Environmental Health Specialist is also not responsible for concealed conditions on the property or for statements in this report that may have resulted from false or misleading statements provided to him in the application. Neither Wake County nor the Environmental Health Specialist warrants that the septic tank system will continue to function satisfactorily in the future or that the water supply will remain potable.


NOTES:
 1. ALL DISTANCES SHOWN ARE HORIZONTAL
 2. PROPERTY SUBJECT TO ALL EASEMENTS
 AND RESTRICTIONS OF RECORD



VICINITY MAP
(NTS)

NORTH
 ↑

0990029
 D-11131
 10212.00
 WARDEN
 RD.



I certify that the location of planned or existing structures are accurately shown. I understand failure to locate structures in accordance with this plot plan may require the relocation of structures regardless degree of completion. I hereby grant permission to Municipal/County Representatives the right of entry to make evaluations or inspections upon this property.

[Signature]
 7/6/98
 Signature of Owner or Authorized Agent

OLD WARDEN ROAD
 0' R/W (PUBLIC) 400'

By *MT*
 Date 7/6/98
 Approve _____
 Revoke _____
 Use 101
 Reject _____
 MBL 30
 Front 30
 Rear 30
 Side 10 Corner _____

Comments:

LOT: 45
 SUBDIVISION: CHANDLER POINTE II
 DATE: 7/6/98
 SCALE: 1" = 50'
 DRAWN BY: JMH
 PROPOSED HOUSE LOCATION
 SOVEREIGN HOMES
 BARTONS CREEK TWP WAKE COUNTY NORTH CAROLINA